

| January 2026 Schedule for Airborne Effluent Releases (Note) | | | |
|--|----------------------------------|---------------------------|------------------------------|
| Source of Airborne Release | Scheduled Release | Type of Activity Released | Estimated Activity in Curies |
| Unit 1 Ventilation | Continuous thru month | Noble Gas | 0.009 |
| | | Tritium | 0.3 |
| | | Particulates | 0.001 |
| Unit 2 Ventilation | Continuous thru month | Noble Gas | 0.1 |
| | | Particulate & Iodines | 0.0005 |
| | | Tritium | 7.0 |
| | | Carbon-14 | 0.9 |
| Unit 2 Waste Gas Decay Tanks | 2 Discharges thru month | Noble Gas | 0.02 |
| | | Tritium | 0.002 |
| Unit 2 Containment Vents | Weekly | Noble Gas | 0.05 |
| | | Tritium | 0.5 |
| Unit 2 Containment Purges | None scheduled | Noble Gas | 0.0 |
| | | Tritium | 0.0 |
| U2 Outage Releases | None scheduled | Noble Gas | 0.0 |
| | | Tritium | 0.0 |
| | | Particulate & Iodines | 0.0 |
| Unit 3 Ventilation | Continuous & Batch thru month | Noble Gas | 2.0 |
| | | Particulate & Iodines | 0.0001 |
| | | Tritium | 7.0 |
| | | Carbon-14 | 1.3 |
| Unit 3 Aux Boiler Blowdown Vent and Secondary Side Systems | Continuous thru month | Tritium | 0.1 |
| Unit 3 Containment Vents | Every 53 hours during Operations | Noble Gas | 0.1 |
| | | Tritium | 0.5 |
| Unit 3 Containment Purges | None scheduled | Noble Gas | 0.0 |
| | | Tritium | 0.0 |
| U3 Outage Releases | None scheduled | Noble Gas | 0.0 |
| | | Particulate & Iodines | 0.000 |
| | | Tritium | 0.0 |
| Unit 3 Containment Drawdown | None scheduled | Noble Gas | 0.0 |
| | | Particulate & Iodines | 0.0 |
| | | Tritium | 0.0 |

Note: Detailed information including any resulting dose consequences will be discussed and listed in the Annual Radioactive Effluent Release Report.