

Energy Saver Rate 6 Application for Residential Existing Homes

(dwelling older than 5 years)

Instructions:

To submit a complete [Rate 6 Energy Saver Application](#), please complete the following steps:

- Ensure your home meets the qualification requirements by providing the following:
 - Provide receipts and/or photographs showing purchase and installation of insulation levels, equipment and all upgrades as listed on the application.
 - Provide an AHRI Certificate to verify SEER2 ratings of all Heating and Cooling equipment.
 - If spray foam insulation is used, provide an equivalency statement from the manufacturer or installer.
 - For homes with an electric tank water heater manufactured prior to 2007, provide a photograph of an installed thermal water heater blanket/wrap or manufacturer's nameplate.
 - For chimney flues and fireplaces, provide a photograph showing tight fitting dampers.

- Complete **ALL** sections of the application and include your **SIGNATURE** and the **DATE** at the bottom of the page.

- [Submit your application via email or USPS mail.](#)

Email: HomeEnergyCheckup@SC.DominionEnergyAccount.com

Mail: Dominion Energy SC Rate 6 Program
Mail Code: Demand Side Management, OSC-2A
220 Operation Way
Cayce, SC 29033

It is the customer's responsibility to submit Rate 6 application and all applicable supporting documentation.
See Rate 6-Energy Saver/Conservation Residential Service for all required documentation.

In order to qualify for residential Rate 6, the home must meet the following criteria:

Ceilings: Ceilings of existing homes shall be insulated with a total "as installed" thermal resistance (R) value of 38 (R-38).

Air Conditioning: Effective September 1, 2021, all cooling systems must have a SEER2 rating at least 1.0 point higher than current ENERGY STAR[®] requirements, with a minimum rating of SEER2 16.

Lighting: Recessed ceiling lights shall be sealed.

Floors: 100% of the exposed earth in a crawl space shall be covered with a vapor barrier of no less than (4) mills.

Windows: Windows shall be insulated (double) glass or have storm windows.

Doors: Doors exposed to full temperature differential (TD) must be weather-stripped on all sides and of solid construction.

Ducts: Air ducts located outside of the conditioned space must have:

1. All joints properly fastened and sealed.
2. The duct shall have a minimum installed insulation of R-value of 8.0
3. All joints in ductwork outside of the conditioned space must be permanently sealed with the application of duct sealant. Transverse joints, take-offs, transitions, supply/return connections to the air handler, boot connections to the floor/ceiling/wall, and framed-in and panned passages must be made airtight with duct sealant.
4. There must be no unnecessary kinks, bends, or slack in flex ducts.

Attic Access: Attic access must be air sealed and insulated to at least R-19.

Water Heaters: Electric water heaters must have a Uniform Energy Factor (UEF) minimum of 0.93 or insulation surrounding the tank.

Other: Chimney flues and fireplaces must have tight fitting dampers.

The "as installed" thermal resistance (R) value for all loose fill or blowing type insulation materials must be verifiable either by installed density using multiple weighted samples, the manufacturer's certification methods, Federal Trade Commission's procedures or other methods specified by local governing agencies.

In the event that Dominion Energy South Carolina, Inc. determines that your residence meets or exceeds the minimum building standards set forth in Rate 6, thereby qualifying your residence for electric service under Rate 6, Dominion Energy South Carolina will begin charging you for electric service under Rate 6 effective with your next monthly billing. Dominion Energy South Carolina will not, however, adjust any past charges for electric service in any manner that will have the effect of applying Rate 6 on a retroactive basis.

HVAC EQUIPMENT

System 1

Manufacturer _____ SEER2 Rating _____

Outdoor Unit Model # _____

Indoor Unit Model # (if applicable) _____

System 2 (if applicable)

Manufacturer _____ SEER2 Rating _____

Outdoor Unit Model # _____

Indoor Unit Model # (if applicable) _____

I certify that the house located at the following address meets these specifications.

Street Address _____

City _____ State _____ Zip _____

I understand that Dominion Energy South Carolina, Inc. may perform an on-site audit to verify this information & customer eligibility.

Dominion Energy Account Number _____

Builder Name _____

Builder Signature _____

Homeowner/Customer Name _____

Homeowner/Customer Signature _____

Please email or mail this information along with your receipts and/or documentation verifying the Rate 6 requirements to:

Email HomeEnergyCheckup@SC.DominionEnergyAccount.com

Mail Dominion Energy SC Rate 6 Program
Mail Code: Demand Side Management, OSC-2A
220 Operation Way
Columbia, SC 29033