




# **ANNUAL CCR FUGITIVE DUST CONTROL REPORT**

Virginia Electric and Power Company  
Dominion – Chesapeake Energy Center  
2701 Veeco Street  
Chesapeake, Virginia 23323

December 15, 2021



## Purpose

The Annual Coal Combustion Residuals (CCR) Fugitive Dust Control Report is produced by Virginia Electric and Power Company d/b/a Dominion Energy Virginia to comply with 40 CFR 257.80(c). This report documents actions to control fugitive dust during the annual period from October 15, 2020 to October 14, 2021.

## Description of Fugitive Dust Controls

The Chesapeake Energy Center employs industry accepted practices for controlling CCR fugitive dust from its operations at the Bottom Ash Pond including the following:

Fugitive Dust Control Practice	Description
Speed limits	Speed limits are strictly enforced to minimize dust generation from truck travel around landfill area.
Water spray of roads	Roads are sprayed routinely to minimize dust from operations and weather.
Road sweeping/scraping	Spilled or tracked CCR is promptly swept or scraped to remove from road or operating area.
Limiting exposed areas	The size of the areas of exposed CCR will be limited to minimize fugitive dust potential.
Use of windbreaks	Windbreaks, temporary or permanent, will be utilized to limit wind exposure to active areas.
Inclement weather work limits	Work that may generate fugitive dust will be limited during inclement weather.

## Citizen Complaints

No citizen complaints were received during the annual period covered by this report.

## Corrective Actions

The CCR fugitive dust controls are sufficient and no corrective actions were necessary.