



INITIAL HAZARD POTENTIAL CLASSIFICATION ASSESSMENT

A world of
capabilities
delivered locally

INITIAL HAZARD POTENTIAL CLASSIFICATION ASSESSMENT

Chesapeake Energy Center CCR Surface
Impoundment: Bottom Ash Pond



**Dominion
Energy**SM

Submitted To: Chesapeake Energy Center
2701 Veeco Street
Chesapeake, VA 23323

Submitted By: Golder Associates Inc.
2108 W. Laburnum Avenue, Suite 200
Richmond, VA 23227

April 2018

Project No. 13-00193





Table of Contents

1.0	Certification	1
2.0	Introduction	2
3.0	Purpose	2
4.0	Assessment.....	3
4.1	Description of the Impounding Structure.....	3
4.2	Drainage Area and Hazard Analysis Area Descriptions	3
4.3	Method of Analysis.....	4
4.4	Failure Analysis Scenarios.....	4
4.5	Hydraulic Modeling Results	5
4.6	Downstream Consequences.....	5
4.7	Spillway Adequacy	5
5.0	Hazard Classification	5
6.0	Conclusions.....	6

Tables

Table 1	Bottom Ash Pond Contributing Drainage Areas
Table 2	1,000-Yr Storm Event and Flows
Table 3	Summary of Peak Discharges, 1,000-Yr Event

Figures

Figure 1	Bottom Ash Pond 1,000-Yr Event Breach Flow
Figure 2	100-Yr Flood Map (FIRM)

Appendices

Appendix A	Figures 1 and 2
Appendix B	Bottom Ash Pond Hydraulic Modeling Analysis

1.0 CERTIFICATION

This Initial Hazard Potential Classification Assessment for the Chesapeake Energy Center's Bottom Ash Pond was prepared by Golder Associates Inc. (Golder). The document and Certification/Statement of Professional Opinion are based on and limited to information that Golder has relied on from Dominion Energy and others, but not independently verified, as well as work products produced by Golder.

On the basis of and subject to the foregoing, it is my professional opinion as a Professional Engineer licensed in the Commonwealth of Virginia that this document has been prepared in accordance with good and accepted engineering practices as exercised by other engineers practicing in the same discipline(s), under similar circumstances, at the same time, and in the same locale. It is my professional opinion that the document was prepared consistent with the requirements in §257.73(a)(2) of the United States Environmental Protection Agency's "Standards for the Disposal of Coal Combustion Residuals in Landfills and Surface Impoundments," published in the Federal Register on April 17, 2015, with an effective date of October 19, 2015 [40 CFR §257.73(a)(2)], as well as with the requirements in §257.100 resulting from the EPA's "Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals From Electric Utilities; Extension of Compliance Deadlines for Certain Inactive Surface Impoundments; Response to Partial Vacatur" published in the Federal Register on August 5, 2016 with an effective date of October 4, 2016 (40 CFR §257.100).

The use of the word "certification" and/or "certify" in this document shall be interpreted and construed as a Statement of Professional Opinion, and is not and shall not be interpreted or construed as a guarantee, warranty, or legal opinion.

Daniel McGrath
Print Name

Associate and Senior Consultant
Title

Daniel McGrath
Signature

4/12/18
Date



2.0 INTRODUCTION

This Initial Hazard Potential Classification Assessment was prepared for the Chesapeake Energy Center's (CEC) inactive Coal Combustion Residuals (CCR) surface impoundment known as the Bottom Ash Pond (BAP). This Hazard Potential Classification Assessment was prepared in accordance with 40 CFR Part §257, Subpart D and is consistent with the requirements of 40 CFR §257.73(a)(2) and 40 CFR §257.100(e)(3)(v).

CEC, owned and operated by Virginia Electric and Power Company d/b/a Dominion Energy Virginia (Dominion), is located in the City of Chesapeake, Virginia at 2701 Veeco Street. The station includes an inactive CCR surface impoundment, the BAP, as defined by the Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule and Direct Final Rule (40 CFR §257; the CCR rule).

This analysis details the purpose, data sources, method of analysis, and development of a map showing the inundation level expected downstream during a breach event of the BAP dam at CEC. The inundation areas were compared with various map sources to determine what, if any, effect on downstream structures could be expected from a breach of the impounding structure. This evaluation covers the current condition of the pond.

3.0 PURPOSE

This certification is required under 40 CFR §257.73(a)(2) and 40 CFR §257.100(e)(3)(v), regarding the hazard potential classification assessment of the BAP at CEC. The purpose of this analysis is to recommend a hazard potential classification for the BAP dam at CEC.

Sources of data used in the analysis included:

- 1) United States Geological Survey (USGS) topographical map (Norfolk South quad sheet 2013);
- 2) Statistical rainfall data from NOAA Atlas 14 (NOAA's Precipitation Frequency Data Server);
- 3) Maps and aerial photos of area roads and structures from the Google Earth Pro;
- 4) Aerial survey of the CEC landfill performed by H&B Surveying and Mapping, LLC, dated July 2015;
- 5) Flood map information from the Federal Emergency Management Agency (FEMA) Flood Insurance Rate Map (FIRM) Community Panel # 5100340024D dated 12/16/2014. (Accessed through ArcGIS – FEMA's National Flood Hazard Layer mapping system);
- 6) Web Soil Survey 2.1, Natural Resources Conservation Service (<http://websoilsurvey.nrcs.usda.gov/app/HomePage.htm>);
- 7) Hurricane Storm Surge Map, City of Chesapeake (<http://gisweb.cityofchesapeake.net/slosh/>);
- 8) Ground survey of the Bottom Ash Pond performed by D&M Surveying, dated January 15, 2018

4.0 ASSESSMENT

4.1 Description of the Impounding Structure

The CEC BAP is located on a peninsula of land bounded on the east side by the Southern Branch of the Elizabeth River, on the west side by the CEC’s discharge canal, and on the south by low lying wetland areas. The BAP embankment is approximately 25 feet wide at the top and has a top elevation of approximately 20 feet above mean sea level (AMSL). The BAP typically does not retain water and has been without a permanent pool of water since the CEC ceased coal-fired operations in 2014. The upstream slopes vary from 3:1 to 2:1 and downstream slopes vary from 2.5:1 to 2:1. The downstream toe is approximately at elevation 1, giving an effective embankment height of 19 feet. The toe of the eastern slope is reinforced with a sheet pile retaining wall.

This study has been developed based on the existing BAP topography as of January 15, 2018. The primary outlet structure is currently a 30-inch diameter Corrugated High Density Polyethylene (CHDPE) pipe that drains to the adjacent sediment basin. There currently is no auxiliary spillway. See Figure 1 for an aerial photo of the BAP dam.

This report has been prepared with the hydraulic models depicting the existing topography and outlet culvert as described in this section.

4.2 Drainage Area and Hazard Analysis Area Descriptions

The drainage area for the BAP consists mainly of grass areas (landfill cover soils) that are presumed to be in good condition for purposes of determining a Runoff Curve Number (CN) as defined by the Natural Resource Conservation Service (NRCS). The soils in the drainage area are primarily Hydrologic Soil Group C. The largest portion of the contributing drainage is from the landfill, with drainage areas consisting of the landfill intermediate cover slopes and the top covered with a geomembrane rain cover. Table 1 below outlines the drainage areas and NRCS curve numbers used in this analysis.

Table 1: Bottom Ash Pond Contributing Drainage Areas

Area Description	Area, Acres	CN
Landfill Cover - grass, good, HSG C	18.94	varies
BA Pond	4.16	79
Total Drainage Area	23.10	

The pond discharges directly into the adjacent sedimentation basin through a 30-inch diameter culvert in the western embankment. South of the dam are low-lying wetland areas, and east of the dam is the Southern Branch of the Elizabeth River. There are no occupied structures downstream of the dam.

4.3 Method of Analysis

To model the inflows into and out of the impoundment, a numerical model was created using the Hydraulic Engineering Center’s Hydrologic Modeling System (HEC-HMS) Version 4.2.1 to generate the anticipated runoff hydrograph from the 24-hour, 1,000-year storm event. Table 2 outlines the resulting inflow and outflow for the non-breach scenario analysis.

Table 2: 1,000-Yr Storm Event and Flows

Storm Event	Rainfall (in)	Peak Inflow (cfs)	Peak Outflow (cfs)	Max Water Elevation (ft)	Inflow Volume (ac-ft)
24-hr, 1,000-Yr	14.6	309.9	41.0	19.04	19.75

For the impounding structure failure analysis, the dam breach routine within HEC-HMS was used to model the failure event and produce the resulting outflow hydrograph. Input values were provided for the embankment geometry, stage-storage relationship, development time, and trigger elevation. The storm-related failure was triggered when the water level in the pond was at its peak.

Due to the simplicity of the downstream geometry, numerical modeling of the breach outflow was not performed. Instead, a general discharge map was generated. Due to the basin’s proximity to the Elizabeth River, the entire area downstream of the bottom ash pond (west, south and east directions) is subject to flooding from the 1% annual chance event (100-Yr event) and is classified as Zone AE on the Flood Insurance Rate Map (FIRM) (reference 6). The elevation given on the FIRM in the area of the basin (8.5 feet AMSL) indicate floodwater levels in the Elizabeth River and Deep Creek would overtop the low-lying wetland areas; however, the basin would not be overtopped (El 20). This is important to note since the storm event used in this analysis is much larger in magnitude than the 1% annual chance event that would cause flooding in the water bodies adjacent to the BAP. The FIRM is included as Figure 2 of this report. A breach of the BAP is not anticipated to impact the CEC or any other developed areas.

4.4 Failure Analysis Scenarios

A breach simulation during the 1,000-year event was conducted to examine the potential downstream impacts of a possible impounding structure failure. In this, the peak outflow in cubic feet per second (cfs) and the maximum high water level downstream was estimated. The breach failure at the 1,000-year event is assumed to be a piping failure through the embankment and not due to overtopping. The breach location was chosen to be in the southern embankment, discharging to the surrounding wetlands and 100-Yr floodplain, as a breach in the eastern embankment into the Elizabeth River would not affect downstream land. The embankment between the BAP and the sedimentation basin is constructed of cemented ash materials and is highly erosion resistant; therefore, a breach event into the sedimentation basin was not evaluated.

A “sunny day” breach is assumed to occur due to piping of soils through the embankment when the water level in the reservoir is at its normal pool elevation; however, there typically is not a normal pool in the BAP so this evaluation was not performed. A seismic analysis was not performed, nor were other sudden failure type scenarios considered as this evaluation is for the potential downstream impacts due to an embankment breach during the design storm event (1,000-yr event).

4.5 Hydraulic Modeling Results

The downstream flood models for the failure scenarios are presented in Table 3. Due to the small magnitude and short flow path for the breach events, detailed hydraulic modeling of the breach outflow was not performed.

Table 3: Summary of Peak Discharges, 1,000-Yr Event

Scenario	Peak Discharge (cfs)	Outflow Volume (ac-ft)
No Breach	41.0	14.01
Breach Event	226.6	18.52

4.6 Downstream Consequences

The modeled embankment failure scenarios may cause erosion damage to the downstream side of the embankment leading to wetland areas/Deep Creek. The effect of the inflow into the Deep Creek/Elizabeth River confluence is anticipated to be minimal, due to the short duration of the flow event and the relatively small volume of the breach flow in comparison to the normal volume of flow in the river.

4.7 Spillway Adequacy

If a structural embankment failure does not occur, the existing 30-inch diameter culvert will adequately pass the 1,000-yr event. At its peak during the 1,000-year event, the basin has approximately 0.96 feet of freeboard. The adjacent sedimentation basin is also capable of receiving the design storm event discharge without overtopping.

5.0 HAZARD CLASSIFICATION

Pursuant to 40 CFR §257.73, a CCR unit is classified as a **Significant Hazard Potential** where failure or mis-operation of the dam results in no probable loss of human life, but can cause economic loss, environmental damage, disruption of lifeline facilities, or impact other concerns. Significant Hazard Potential classification dams are often located in predominantly rural or agricultural areas, but could be located in areas with population and significant infrastructure. The potential inundation zone downstream of the BAP dam embankment does not contain occupied structures, nor is it regularly occupied by plant personnel.


6.0 CONCLUSIONS

The results of this analysis show a breach of this impounding structure during a storm event has no downstream impacts to manmade structures, and failure or mis-operation of the dam is unlikely to result in loss of human life. Therefore, the BAP dam in its current condition is assigned a hazard potential rating of “Significant” as defined under 40 CFR §257.73.





APPENDIX A - Figures

Figure 1 – Bottom Ash Pond 1,000-Yr Event Breach Flow
Figure 2 – 100-Yr Flood Map (FIRM)

Path: G:\Plan Production Data Files\Drawing Data Files\13-00193\13-00193.dwg - Batch Analysis\kshksh.dwg 13/01/2018 05:40g




LEGEND

-  AREA SUBJECT TO FLOOD FLOW AND VELOCITY
-  100 YEAR FLOOD PLAIN BOUNDARY (ZONE AE)
-  PROPERTY LINE
-  BOTTOM ASH POND LIMITS

NOTES

1. MAPPING OF FLOODED AREAS AND FLOOD WAVE TRAVEL TIMES ARE APPROXIMATE. TIMING AND EXTENT OF ACTUAL INUNDATION MAY DIFFER FROM INFORMATION PRESENTED ON THIS MAP.
2. THE PROPERTY BOUNDARY SHOWN ON THIS DRAWING IS AS SUBMITTED BY H & B SURVEYING AND MAPPING, LLC., DECEMBER 19, 2014.
3. 100 YEAR FLOOD PLAIN BOUNDARY TAKEN FROM PHOTOGRAMMETRIC AERIAL SURVEY PERFORMED ON 07/10/2015 BY MCKENZIE SNYDER, INC.
2. BASE MAP CONSISTS OF GOOGLE EARTH AERIAL IMAGE DATED 11/05/2016 RETRIEVED ON 01/24/2018.



CLIENT
DOMINION ENERGY

CONSULTANT	2018-01-25
DESIGNED	DPM
PREPARED	ABR
REVIEWED	
APPROVED	



PROJECT
CHESAPEAKE ENERGY CENTER
DCR INVENTORY #00441
CHESAPEAKE, VIRGINIA

TITLE
**BOTTOM ASH POND
1,000-YEAR EVENT BREACH FLOW**

PROJECT NO.
13-00193

REV.
0

FIGURE
1

1 in. IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET SIZE HAS BEEN MODIFIED FROM ANSIB

National Flood Hazard Layer FIRMette



36°45'56.82"N



Legend

SEE FIS REPORT FOR DETAILED LEGEND AND INDEX MAP FOR FIRM PANEL LAYOUT

SPECIAL FLOOD HAZARD AREAS		Without Base Flood Elevation (BFE) Zone A, V, A99
		With BFE or Depth Regulatory Floodway Zone AE, AO, AH, VE, AR
OTHER AREAS OF FLOOD HAZARD		0.2% Annual Chance Flood Hazard, Areas of 1% annual chance flood with average depth less than one foot or with drainage areas of less than one square mile Zone X
		Future Conditions 1% Annual Chance Flood Hazard Zone X
		Area with Reduced Flood Risk due to Levee. See Notes. Zone X
		Area with Flood Risk due to Levee Zone D
OTHER AREAS		Area of Minimal Flood Hazard Zone X
		Effective LOMRs
		Area of Undetermined Flood Hazard Zone D
GENERAL STRUCTURES	- - -	Channel, Culvert, or Storm Sewer
		Levee, Dike, or Floodwall
OTHER FEATURES		Cross Sections with 1% Annual Chance Water Surface Elevation
		Coastal Transect
		Base Flood Elevation Line (BFE)
		Limit of Study
		Jurisdiction Boundary
		Coastal Transect Baseline
MAP PANELS		Digital Data Available
		No Digital Data Available
		Unmapped

This map complies with FEMA's standards for the use of digital flood maps if it is not void as described below. The base map shown complies with FEMA's base map accuracy standards

The flood hazard information is derived directly from the authoritative NFHL web services provided by FEMA. This map was exported on 3/7/2018 at 11:26:11 AM and does not reflect changes or amendments subsequent to this date and time. The NFHL and effective information may change or become superseded by new data over time.

This map image is void if the one or more of the following map elements do not appear: base map imagery, flood zone labels, legend, scale bar, map creation date, community identifiers, FIRM panel number, and FIRM effective date. Map images for unmapped and unmodernized areas cannot be used for regulatory purposes.

Figure 2

APPENDIX B


Bottom Ash Pond Hydraulic Modeling Analysis

BAP - North Section

ELEVATION	AREA (SF)	AREA (AC)
15	5067	0.12
16	13,341	0.31
17	20,928	0.48
18	28,572	0.66
19	36,436	0.84

BAP - South Section

ELEVATION	AREA (SF)	AREA (AC)
13	203	0.0047
14	20901	0.48
15	45858	1.05
16	64,500	1.48
17	77,178	1.77
18	84,547	1.94
19	92,312	2.12
20	153,740	3.53



Combined Sections stage storage

ELEVATION	AREA (SF)	VOLUME, ft ³	AC-FT	TOTAL
20	153,740	141,059	3.24	12.89
19	128,748	120,849	2.77	9.66
18	113,119	105,523	2.42	6.88
17	98,106	87,778	2.02	4.46
16	77,841	63,909	1.47	2.44
15	50,925	34,817	0.80	0.98
14	20,901	7,721	0.18	0.18
13	203	0	0	0

Drainage Areas for Partial Excavation

Area Description	Size, Ac.	CN	H _L	Slope, ft/ft	T _L , min	Drains to
Top Rain Cover	3.246	98	873	0.01	8.10	RR Channel
North Slope	5.496	61	335	0.131	3.71	East Channel
East Slope	8.206	61	297	0.145	3.20	East Channel (half)
South Slope	1.994	61	363	0.118	4.16	BA Pond
BA Pond Proper	4.157	79	120	0.075	1.32	Self

Drainage Areas for Sediment Basin

Area Description	Size, Ac.	CN	H _L	Slope, ft/ft	T _L , min	Drains to
West Slope	8.03	61	297	0.145	3.20	West Channel
Sed Basin Proper	6.41	77	120	0.075	1.40	Self

Assumed k for bottom ash:	0.005	cm/s
Pond floor constant (q):	1.64E-04	CFS/ft2

30" CPP Rating	
Elevation	Q out (CFS)
14	0
15.15	0
15.25	0.1
15.5	0.60
15.75	2.00
16	3.80
16.25	6.20
16.5	8.80
16.75	11.70
17	15.10
17.25	18.70
17.5	22.50
17.75	26.20
18	29.60
18.25	32.70
18.5	35.50
18.75	38.10
19	40.60
19.25	42.90
19.5	45.00
19.75	47.10
20	49.00

Pond Floor*	
Elevation	Q out (CFS)
14	0
15.15	0.831
15.25	0.831
15.5	0.831
15.75	0.831
16	2.189
16.25	2.189
16.5	2.189
16.75	2.189
17	3.433
17.25	3.433
17.5	3.433
17.75	3.433
18	4.687
18.25	4.687
18.5	4.687
18.75	4.687
19	5.977
19.25	5.977
19.5	5.977
19.75	5.977
20	5.977

*pond floor area = only northern section area due to road

Sediment pond elevation-area as of 1/15/18

ELEVATION	AREA (SF)	AREA (ACRES)
10	142,846	3.28
11	158,617	3.64
12	169,987	3.90
13	180,322	4.14
14	191,892	4.41
15	201,158	4.62
16	210,383	4.83
17	219,732	5.04
18	229,705	5.27
19	242,218	5.56
20	279,160	6.41



Golder Associates Inc.

CEC Existing Stormwater Basin Riser

Weir 1 elevation	10.45
Weir 1 length	11
Orifice 1 area	9.62
Weir discharge coefficient	3.3
Orifice discharge coefficient	0.6

Culvert Outlet from UD culvert:	
Inv in	4
Inv out	-2.1
Length	129
Dia	21 inches (24" SDR-17 HDPE)
Slope	0.0473
Tw El	2

Elevation	Weir 1	Orifice 1	Min	Culvert	Rating
10.45				0.00	0.00
10.5	0.41	0.05	0.05	35.80	0.05
10.75	5.96	0.79	0.79	36.60	0.79
11	14.81	1.96	1.96	37.40	1.96
11.25	25.97	3.45	3.45	38.20	3.45
11.5	39.06	5.18	5.18	38.90	5.18
11.75	53.80	7.14	7.14	39.70	7.14
12	70.05	9.29	9.29	40.40	9.29
12.25	87.66	11.63	11.63	41.10	11.63
12.5	106.55	14.13	14.13	41.80	14.13
12.75	126.62	16.80	16.80	42.50	16.80
13	147.81	19.61	19.61	43.20	19.61
13.25	170.08	22.56	22.56	43.90	22.56
13.5	193.36	25.65	25.65	44.50	25.65
13.75	217.61	28.86	28.86	45.20	28.86
14	242.80	32.21	32.21	45.80	32.21
14.25	268.89	35.67	35.67	46.40	35.67
14.5	295.86	39.24	39.24	47.10	39.24
14.75	323.68	42.93	42.93	47.70	42.93
15	352.31	46.73	46.73	48.30	46.73
15.25	381.74	50.64	50.64	48.90	48.90
15.5	411.95	54.64	54.64	49.50	49.50
15.75	442.92	58.75	58.75	50.10	50.10
16	474.62	62.96	62.96	50.60	50.60
16.25	507.05	67.26	67.26	51.20	51.20
16.5	540.18	71.65	71.65	51.80	51.80
16.75	574.01	76.14	76.14	52.30	52.30
17	608.51	80.72	80.72	52.90	52.90
17.25	643.68	85.38	85.38	53.40	53.40
17.5	679.50	90.13	90.13	54.00	54.00
17.75	715.96	94.97	94.97	54.50	54.50
18	753.06	99.89	99.89	55.00	55.00
18.25	790.77	104.89	104.89	55.60	55.60
18.5	829.09	109.97	109.97	56.10	56.10
18.75	868.01	115.14	115.14	56.60	56.60
19	907.52	120.38	120.38	57.10	57.10
19.25	947.61	125.70	125.70	57.60	57.60
19.5	988.28	131.09	131.09	58.10	58.10
19.75	1029.51	136.56	136.56	58.60	58.60
20	1071.30	142.10	142.10	59.10	59.10



Reservoir Dam Break Options

Basin Name: BA Partial Excavation
Element Name: BA Pond Partial

Method: Piping Breach

Direction: Main

*Top Elevation (FT) 20

*Bottom Elevation (FT) 13

*Bottom Width (FT) 2.1

*Left Slope (xH:1V) 0.5

*Right Slope (xH:1V) 0.5

*Piping Elevation (FT) 16

*Piping Coefficient: 0.6

*Development Time (HR) 0.18

Trigger Method: Elevation

*Trigger Elevation (FT) 19.03

Progression Method: Linear

HEC-HMS Breach Parameters

Summary Results for Reservoir "BA Pond Partial"

Project: CEC Dam Alteration Simulation Run: BA Partial 24-Hr 1000-Yr
 Reservoir: BA Pond Partial

Start of Run: 10Jul2015, 00:00 Basin Model: BA Partial Excavation
 End of Run: 11Jul2015, 00:01 Meteorologic Model: 24-Hr 1000-Yr
 Compute Time: 23Jan2018, 14:47:39 Control Specifications: 24-hr

Volume Units: IN AC-FT

Computed Results

Peak Inflow: 309.9 (CFS)	Date/Time of Peak Inflow: 10Jul2015, 11:58
Peak Discharge: 41.0 (CFS)	Date/Time of Peak Discharge: 10Jul2015, 12:24
Inflow Volume: 19.75 (AC-FT)	Peak Storage: 9.81 (AC-FT)
Discharge Volume: 14.01 (AC-FT)	Peak Elevation: 19.04 (FT)

HEC-HMS Summary Output, non-breach

Summary Results for Reservoir "BA Pond Partial"

Project: CEC Dam Alteration Simulation Run: BA Partial 24-Hr 1000-Yr
 Reservoir: BA Pond Partial

Start of Run: 10Jul2015, 00:00 Basin Model: BA Partial Excavation
 End of Run: 11Jul2015, 00:01 Meteorologic Model: 24-Hr 1000-Yr
 Compute Time: 23Jan2018, 14:45:26 Control Specifications: 24-hr

Volume Units: IN AC-FT

Computed Results

Peak Inflow: 309.9 (CFS)	Date/Time of Peak Inflow: 10Jul2015, 11:58
Peak Discharge: 226.6 (CFS)	Date/Time of Peak Discharge: 10Jul2015, 12:30
Inflow Volume: 19.75 (AC-FT)	Peak Storage: 9.79 (AC-FT)
Discharge Volume: 18.52 (AC-FT)	Peak Elevation: 19.04 (FT)

HEC-HMS Summary Output, breach event

Established in 1960, Golder Associates is a global, employee-owned organization that helps clients find sustainable solutions to the challenges of finite resources, energy and water supply and management, waste management, urbanization, and climate change. We provide a wide range of independent consulting, design, and construction services in our specialist areas of earth, environment, and energy. By building strong relationships and meeting the needs of clients, our people have created one of the most trusted professional services organizations in the world.

Africa	+ 27 11 254 4800
Asia	+ 852 2562 3658
Australasia	+ 61 3 8862 3500
Europe	+ 356 21 42 30 20
North America	+ 1 800 275 3281
South America	+ 56 2 2616 2000

solutions@golder.com
www.golder.com

Golder Associates Inc.
2108 W. Laburnum Avenue, Suite 200
Richmond, VA 23227 USA
Tel: (804) 358-7900
Fax: (804) 358-2900



Engineering Earth's Development, Preserving Earth's Integrity

Golder, Golder Associates and the GA globe design are trademarks of Golder Associates Corporation