



North Sludge Sedimentation Basin Retrofit Completion Notification

**Clover Power Station
Clover, Virginia**

August 2018

*Prepared For
Virginia Electric and Power Company*

*TRC Environmental Corporation | Virginia Electric and Power Company
North Sludge Sedimentation Basin
Retrofit Completion Notification
Clover Power Station, Clover, Virginia
Final*

\\greenville-fp1\WPGVL\PJT2\232002\0001\R2320020001-0017 - North Basin Retrofit Notification of Completion.docx

Section 1

Notification of Completion

Virginia Electric and Power Company d/b/a Dominion Virginia Power (Dominion) owns and operates the Clover Power Station¹ (Station). The Station currently operates two Sludge Sedimentation Basins (North and South Basins; basins) that store and manage flue gas desulfurization (FGD) sludge. The basins are therefore considered Coal Combustion Residuals (CCR) surface impoundments as defined in the Standards for the Disposal of CCR in Landfills and Surface Impoundments (federal CCR rule). Dominion is submitting this notification that retrofit activities specified in 40 Code of Federal Regulations (CFR) 257.102(k)(1) and as described in the Retrofit Plan for CCR Surface Impoundments Pond dated May 2016 (Updated July 2017) were completed for the North Basin on July 31, 2018.

¹ The Clover Power Station and associated CCR units are jointly and equally owned by Dominion Virginia Power and Old Dominion Electric Cooperative (ODEC).

Section 2 Certification

I, the undersigned Virginia Professional Engineer, hereby certify that I am familiar with the technical requirements of 40 CFR 257.102. I also certify that it is my professional opinion that, to the best of my knowledge, information, and belief, that the activities outlined in the Retrofit Plan for CCR Surface Impoundments have been completed in accordance with current good and accepted construction and engineering practice(s) and standard(s) appropriate to the nature of the project and the technical requirements of 40 CFR 257.102 (k)(2).

For the purpose of this document, "certify" and "certification" shall be interpreted and construed to be a "statement of professional opinion". The certification is understood and intended to be an expression of my professional opinion as a Virginia Registered Professional Engineer, based upon knowledge, information, and belief. The statement(s) of professional opinion are not and shall not be interpreted or construed to be a guarantee or a warranty of the retrofit activities.

R. Kent Nilsson

Printed Name of Professional Engineer



Signature of Professional Engineer

026477

State of Virginia License Number

August 6, 2018

Date

