



Post-Closure Care Plan for the CCR Surface Impoundments

**Clover Power Station
Clover, Virginia**

November 2021

*Prepared For
Virginia Electric and Power Company*

A handwritten signature in blue ink, appearing to read "Nakia W. Addison", is written over a horizontal line.

Nakia W. Addison, P.E.
Senior Engineer

*TRC Environmental Corporation | Virginia Electric and Power Company
Post-Closure Care Plan for the CCR Surface Impoundments
Clover Power Station, Clover, Virginia
Final*

\\GREENVILLE-FP1\WPGVL\PJT2\463792\R4637920000-002 - CLOVER POST-CLOSURE PLAN.DOCX

Post-Closure Care Requirement

Virginia Electric and Power Company d/b/a Dominion Energy Virginia (Dominion) owns and operates the Clover Power Station (Station). The Station operates two Coal Combustion Residual (CCR) Surface Impoundments (North and South Sludge Sedimentation Basins; basins), which meet the definition of coal combustion residual (CCR) surface impoundments under the United States Environmental Protection Agency (USEPA) Disposal of Coal Combustion Residuals From Electric Utilities Final Rule (CCR Rule). The basins will be closed in accordance with 40 CFR 257.102(c) through the removal of CCR such that no residual materials remain visible and decontamination of the area is certified by a professional engineer licensed in Virginia. Consistent with the requirements of 40 CFR §257.104(a)(2) for post-closure care of CCR surface impoundments, a Post-Closure Care Plan is not required for a surface impoundment that closed through CCR removal under 40 CFR 257.102(c). Therefore, a Post-Closure Care Plan for the basins has not been developed.