

Low Volume Waste Settling Ponds
Initial Inflow Design Flood Control System Plan

**Mount Storm Power Station
Mount Storm, West Virginia**

October 2016



Low Volume Waste Settling Ponds Initial Inflow Design Flood Control System Plan

Mount Storm Power Station
Mount Storm, West Virginia

October 2016

Prepared For
Virginia Electric and Power Company

A handwritten signature in blue ink that reads "Jonathan Hotstream".

Jonathan Hotstream
Senior Scientist

A handwritten signature in blue ink that reads "R. Kent Nilsson".

R. Kent Nilsson, P.E.
Senior Engineer

TRC Engineers, Inc. | Virginia Electric and Power Company – Mt. Storm Power Station
Low Volume Waste Settling Ponds - Initial Inflow Design Flood Control System Plan
Final

\\NTAPA-GRNVILLE\GVL-VOL5\-\WPGVL\PJ12\230765\0000\000001\R2307650000PH1-002.DOCX

© 2016 TRC
All Rights Reserved

Table of Contents

Revision History.....	ii
1. Background	1
1.1 Existing Conditions.....	1
1.2 Pond Retrofit and Reconstruction Design	2
2. Inflow Design Flood Control	3
2.1 LVWSP Operation.....	3
2.2 System Hydraulics	4
2.3 Storm Water Control.....	4
2.4 Conclusions.....	4
3. Amendment and Periodic Plan Revision	5
4. References	6
5. Certification.....	7

List of Figures

Figure 1	Site Location Map
Figure 2	Site Overview Map

List of Appendices

Appendix A	Select Engineering Drawings
Appendix B	Flood Insurance Rate Map
Appendix C	Storm Water Calculations

Revision History

REVISION NUMBER	REVISION DATE	SECTION REVISED	SUMMARY OF REVISIONS

Section 1

Background

Virginia Electric and Power Company d/b/a Dominion Virginia Power (Dominion) owns and operates the Mount Storm Power Station (Station). The Station manages coal combustion residuals (CCR) in five existing low volume waste settling ponds (LVWSP) (Pyrite Pond and Ponds A, B, C, and D). The purpose of this Inflow Design Flood Control System Plan (Plan) is to present the designed and constructed flood control features of the five existing LVWSP and the proposed retrofitted and reconstructed LVWSP at the Station that will be used to manage the inflow design flood as required by the United States Environmental Protection Agency's (USEPA) final coal combustion residual (CCR) rule (Title 40 Code of Federal Regulations (40 CFR) Parts 257 and 261) Subpart D-“Standards for the Disposal of Coal Combustion Residuals in Landfills and Surface Impoundments.” The LVWSP are considered existing CCR surface impoundments according to the CCR rule (40 CFR 257.53).

1.1 Existing Conditions

The Station is located in Union District, Grant County, West Virginia (refer to Figure 1). There are currently five LVWSP at the Station (refer to Figure 2). The area including the LVWSP is approximately nine acres with the surrounding terrain sloping down toward Mount Storm Lake to the east and south from the topographic high on the northwest side of the LVWSP. The normal water elevation for Mount Storm Lake is approximately 3245 feet NAVD88 with a maximum elevation of 3248.3 feet NAVD88. The water levels of Mount Storm Lake are controlled by the Mount Storm Lake Dam which is operated by Dominion.

The LVWSP receive influent water from dewatering bin overflows and area sumps, along with water from Station drain systems, the oily water separator system, storm water, and other Station drains. The water flows to a pH neutralizing system before flowing to the primary ponds (Ponds A and B) for settling. After the primary ponds, water flows into a secondary ponds (Ponds C and D) for additional settling. From the secondary ponds, water is discharged into Mount Storm Lake via a National Pollutant Discharge Elimination System permitted outfall. The four pond configuration allows one pond to be dredged and cleaned while maintaining the other LVWSP in service to process wastewaters.

The Pyrite Pond receives primarily storm water inflows upstream of Ponds A through D. The Pyrite Pond discharges to the pH neutralizing system prior to flowing into the primary settling LVWSP.

The wastewater flows through several outlet structures in a circuit through the LVWSP. The water flow is driven by gravity. Station personnel can control flow to and from a pond by operating gates on the outlet structures.

The LVWSP are located on the south side of the station and were constructed in partial cut with an earthen berm constructed on the southern perimeter berm of Pond D and the eastern and western berms of Ponds C and D. The dividing berms between Ponds A and B and Ponds C and D were constructed of fill after the original excavation of the LVWSP. The geometry of each pond varies. The maximum depth of water is maintained in Pond A with an approximate pond bottom elevation of 3244 feet NAVD88 and a top of berm elevation of 3260 feet NAVD88. Appendix A provides the existing conditions for the LVWSP.

1.2 Pond Retrofit and Reconstruction Design

Dominion plans to retrofit the Pyrite Pond, close Ponds A through D, and reconstruct Ponds A and B in accordance with 40 CFR 257.102 between 2016 and 2018. The final configuration of the LVWSP will have three ponds: Pyrite Pond, Pond A, and Pond B. Refer to Appendix A for engineering drawings presenting the proposed retrofit, closure, and reconstruction.

The retrofitted and reconstructed LVWSP were designed to operate at the same flow capacity as the existing conditions. Therefore, the retrofitted and reconstructed LVWSP will provide the same level of flood control as the existing LVWSP.

Section 2

Inflow Design Flood Control

Hydrologic and hydraulic capacity requirements for existing and new CCR surface impoundments are provided in 40 CFR 257.82. The Station LVWSP were classified as low hazard in accordance with 40 CFR 257.73 and 40 CFR 257.74. Based on the low hazard potential classification, the CCR units must adequately manage flow into the unit during and following the peak discharge of the 100-year flood (40 CFR 257.82(a)(3)(iii)).

The Mount Storm LVWSP were designed in a manner consistent with 40 CFR 257.82(a)(1), (2) and (3), which allows CCR units to adequately manage inflows during and following peak discharge and to manage outflows to collect and control peak discharge for a 100 year flood due to the low hazard classification.

The Flood Insurance Rate Map for the Station (National Flood Insurance Program 2009) shows that the LVWSP are located in an area determined to be outside the 0.2% annual chance flood (refer to Appendix B). Figures 1 and 2 show the extent of the 100 year flood plain is not mapped in the vicinity of the station. The existing and retrofitted LVWSP are located in an area that is above the 100 year flood elevation; therefore, a dedicated flood control system is not required. The LVWSP have been designed with several inflow design features presented in the sections below.

2.1 LVWSP Operation

The reconstructed Pond A and Pond B will operate in a manner similar to the current LVWSP configuration. The LVWSP are utilized to treat process waste water following the pH treatment system. The current Ponds A and B are designed to be operated in parallel. The current LVWSP were designed to operate at a maximum water elevation of 3255.1 feet NAVD88, which is approximately five feet below the top of berm height at 3260 feet NAVD88. The maximum water level in Pond A and Pond B is limited by the flow capacity of the upgradient hydraulic system. The water level within the active LVWSP are monitored daily by on-site personnel. High level alarms will be installed on the new filter equipment located downstream of the LVWSP prior to discharge.

The inflow to the Pyrite Pond is controlled by a splitter box from the Station and is also the primary pond for controlling surface water discharge across the site. The Pyrite Pond discharges to the pH treatment system upstream of Ponds A and B.

The following control measures are implemented during pond operations to control the water levels in the LVWSP:

- Regularly drain and clean ash hydrobins, in a manner to not exceed designed flow rate.
- Regularly remove settled solids from Ponds A and B to provide optimal system performance and maximum capacity.
- Operate outlet structures to control the pond water levels.
- Regularly check and maintain grades surrounding the LVWSP to minimize the area contributing to storm water run-on.

2.2 System Hydraulics

Based on instantaneous measurements for the existing LVWSP outlet, the current maximum outflow is approximately 26 million gallons per day (MGD). The system hydraulics for the retrofit and reconstruction has been designed to provide flow capacities up to the design maximum of 26 MGD through the LVWSP.

2.3 Storm Water Control

The LVWSP were designed to control the storm water run-on from a 100 year, 24 hour storm event based upon the Precipitation Frequency Estimates from the National Oceanic and Atmospheric Administration. The Pyrite Pond collects storm water runoff from areas outside of the LVWSP and routes it through the downstream LVWSP. Culverts bring storm water into the Pyrite Pond from across the station with the most significant contribution coming from the coal pad.

The LVWSP were designed to operate with at least two feet of freeboard, height from the design water elevation to the top of berm elevation. The storm water run-on volume calculated for the design storm were compared to the storage capacity above the LVWSP design operating elevation. The evaluation determined that there is sufficient capacity in the LVWSP when operating at the design water elevations (refer to Appendix C).

2.4 Conclusions

The existing and designed retrofit and reconstructed LVWSP meet the requirements of 40 CFR 257.82 of adequately controlling the inflows during and after peak discharge of the 100-year flood at the Mount Storm Power Station for the following reasons:

- The LVWSP are located above the 100 year floodplain.
- The LVWSP were adequately designed to withstand a 100 year, 24 hour storm event.
- The pond capacities are sufficient to control the water levels and provide freeboard.

Section 3

Amendment and Periodic Plan Revision

This Plan was been completed in compliance with the requirements set forth in 40 CFR 257.82. The WV Department of Environmental Protection will be notified once this document has been placed in the operating record and posted to the publicly accessible website. A periodic inflow design flood control system plan must be prepared every 5 years from the completion date of this Plan.

The Plan must be amended whenever the periodic review period is reached or if changes in site conditions occur that will sustainably affect the current written plan.

Section 4 References

National Flood Insurance Program. 2009. Flood Insurance Rate Map: Grant County West Virginia, and Incorporated Areas Panel 135 of 425. Map Number 54023C0135F. Effective Date September 2, 2009. Federal Emergency Management Agency. Washington, D.C.

TRC Engineers, Inc. 2016. Initial Hazard Potential Classification – Low Volume Waste Settling Ponds Mount Storm Power Station. October 2016.

Section 5 Certification

I, the undersigned West Virginia Professional Engineer, hereby certify that I am familiar with the technical requirements of 40 CFR 257 Subpart D. I also certify that it is my professional opinion that, to the best of my knowledge, information, and belief, that the information in this demonstration is in accordance with current good and accepted engineering practice(s) and standard(s) and meets the requirements of paragraph (a) of in 40 CFR 257.82.

For the purpose of this document, “certify” and “certification” shall be interpreted and construed to be a “statement of professional opinion.” The certification is understood and intended to be an expression of my professional opinion as a West Virginia Licensed Professional Engineer, based upon knowledge, information, and belief. The statement(s) of professional opinion are not and shall not be interpreted or construed to be a guarantee or a warranty of the analysis herein.

R. Kent Nilsson, P.E.
Printed Name of Professional Engineer


21543
State of West Virginia License Number


Signature of Professional Engineer

October 3, 2016
Date



**SURFACE
IMPOUNDMENTS**



Legend



DIRECTION OF SURFACE
WATER FLOW




WEST VIRGIN A

-BASE MAP FROM USGS 7.5 MINUTE TOPOGRAPHIC QUADRANGLE SERIES, 2011.
-THERE ARE NO 100 YEAR FLOODPLAIN AREAS LOCATED WITHIN THE EXTENTS OF THIS MAP.



1" = 2,000'
1:24,000



Patewood Plaza One, Suite 300
30 Patewood Drive
Greenville, SC 29615
Phone: 864.281.0030

**DOMINION RESOURCES SERVICES, INC.
MOUNT STORM POWER STATION
MOUNT STORM, GRANT COUNTY, WEST VIRGINIA**

**INITIAL HAZARD POTENTIAL CLASSIFICATION
SITE LOCATION MAP**

DRAWN BY:	R SUEMNICHT
APPROVED BY:	R. K. NILSSON
PROJECT NO:	230765
FILE NO.	230765-004slm.mxd
DATE:	AUGUST 2016



-BASE MAP IMAGERY FROM ESRI/BING, 2011.
 -THERE ARE NO 100 YEAR FLOODPLAIN AREAS LOCATED WITHIN THE EXTENTS OF THIS MAP.



Patwood Plaza One, Suite 300
 30 Patwood Drive
 Greenville, SC 29615
 Phone: 864.281.0030

**DOMINION RESOURCES SERVICES, INC.
 MOUNT STORM POWER STATION
 MOUNT STORM, GRANT COUNTY, WEST VIRGINIA**


**INITIAL HAZARD POTENTIAL CLASSIFICATION
 SITE OVERVIEW MAP**

DRAWN BY:	R SUEMNICHT
APPROVED BY:	R. K. NILSSON
PROJECT NO:	230765
FILE NO.	230765-005slm.mxd
DATE:	AUGUST 2016


FIGURE 2

Appendix A

Select Engineering Drawings



- NOTES**
- REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.
 - * - INDICATES THAT INFORMATION IS BASED ON REVIEW OF DOMINION DESIGN DRAWINGS AND INFORMATION PROVIDED BY DOMINION PERSONNEL DURING THE SURVEY. THIS INFORMATION SHOULD BE CONSIDERED APPROXIMATE.
 - SOIL BORING SYMBOLS REPRESENT LOCATIONS WHERE BORINGS TAKEN.
 - CONTRACTOR SHALL RELOCATE EXISTING CONTAINERS ON-SITE AS DIRECTED BY OWNER. CONTRACTOR SHALL PROVIDE THREE (3) REPLACEMENT CONTAINERS (WITH ROOFS) OF THE SAME SIZE AS EXISTING AND LOCATE ON SITE AS DIRECTED BY THE OWNER.
 - ITEMS TO BE ABANDONED/REMOVED SHALL BE DONE IN ACCORDANCE WITH THE OVERALL PROJECT SCHEDULE.
 - ABANDONED STRUCTURES SHALL BE FILLED WITH NON-SHRINK GROUT. STRUCTURES AND PIPES TO BE ABANDONED MAY BE REMOVED AS NEEDED TO FACILITATE NEW CONSTRUCTION.
 - CONTRACTOR SHALL PROVIDE ALL LABOR, MATERIALS, EQUIPMENT AND SUPERINTENDENCE TO PROVIDE THE DEMOLITION WORK.
 - THE OWNER ASSUMES NO RESPONSIBILITY FOR THE ACTUAL CONDITION OF THE STRUCTURES TO BE DEMOLISHED OR MODIFIED.
 - ALL REMOVED CONCRETE/STRUCTURES SHALL BE BACKFILLED TO MATCH FINISHED GRADE AS SHOWN IN THE PLANS.
 1. THE LOCATION OF THE LEACHATE TRANSFER PIPING IS BASED ON THE DESIGN LAYOUT PROVIDED IN DRAWING 896 2X-C-002 REV. 1 AND PLANT PERSONNEL DESCRIPTION OF CONSTRUCTION. LOCATION IS APPROXIMATE.



MT. STORM LAKE
W.E. = 3243.57 (07/08/2015)



Dominion
POWER GENERATION ENGINEERING
RICHMOND, VIRGINIA



EXISTING CONDITIONS AND DEMOLITION PLAN
LWSP CLOSURE & RECONSTRUCTION - PHASE 1
MOUNT STORM POWER STATION, WEST VIRGINIA




WARNING! EXISTING UNDERGROUND ELECTRIC LINE. EXACT LOCATIONS AND DEPTHS UNKNOWN. INSTALLER TO VERIFY PRIOR TO EXCAVATION

RELOCATE EXISTING TRANSFER PIPES; ADDED NOTE 10 TO LIST OF NOTES; ADDED 3 MANHOLES TO PIPE LINE.

1 RE-ISSUED FOR BID 0 ISSUED FOR BID

REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	



WATER SURFACE ELEVATIONS

LOCATION	DESCRIPTION	WEIR ELEVATION	WATER SURFACE ELEVATIONS		
			MIN. (10.6 MGD)	DESIGN (20 MGD)	MAX (26 MGD)
①	PYRITE POND	-	3237.68	3267.77	3267.85
②	PYRITE POND OUTLET STRUCTURE WEIR	VARIABLE	3267.62	3267.68	3267.74
③	PYRITE POND OUTLET STRUCTURE	-	3267.12	3267.18	3267.24
④	POND A/B DISTRIBUTION BOX OVERFLOW	-	3257.05	3257.25	3257.36
⑤	POND A/B DISTRIBUTION BOX	-	3254.03	3255.06	3256.38
⑥	POND A/B	-	3253.79	3254.24	3255.11
⑦	POND A/B OUTLET STRUCTURE WEIR	VARIABLE	3253.50	3253.80	3254.57
⑧	POND A/B OUTLET STRUCTURE	-	3252.37	3253.30	3254.09
⑨	JUNCTION BOX D	-	3252.32	3253.13	3253.97
⑩	JUNCTION BOX A	-	3252.24	3252.87	3253.78
⑪	JUNCTION BOX C	-	3252.20	3252.74	3253.69
⑫	FILTER INLET WEIR OVERFLOW	-	3252.07	3252.28	3252.81
⑬	FILTER INLET WEIR	3251.08 (FIXED)	-	-	-
⑭	FILTER BACKWASH INITIATE	FIXED	3252.54	3252.54	3252.54
⑮	FILTER OUTLET WEIR OVERFLOW	-	3250.07	3250.28	3250.20
⑯	FILTER OUTLET WEIR	3249.68 (FIXED)	-	-	-
⑰	FILTER OUTLET BOX	-	3248.41	3248.69	3248.95
⑱	JUNCTION BOX B	-	3248.33	3248.40	3248.54
⑲	MT STORM LAKE	MAX WSE	3248.30	3248.30	3248.30

NOTES:

- ELEVATIONS OF EXISTING LIME BUILDING ARE APPROXIMATE.
- MIN. FLOW = 10.6 MGD
DES. FLOW = 20 MGD
MAX. FLOW = 26 MGD

PLAN LEGEND

- PROPOSED STRUCTURES
- EXISTING STRUCTURES
- FUTURE STRUCTURES

6/16/2016

**POWER GENERATION ENGINEERING
RICHMOND, VIRGINIA**

PROPOSED HYDRAULIC PROFILE
LWSP CLOSURE & RECONSTRUCTION – PHASE 1
MOUNT STORM POWER STATION, WEST VIRGINIA




DSGN	SMOBBLEY	DSGN SUPV	_____	DATE	JUNE 2016	DNNSPEC FOR FILE VERIFICATION
DRWN	AREYES	ENGR SUPV	_____	DRAWING NO.	66703-C3	REV. 1
CHKD	CBELL	PROJ ENGR	_____			
DISPL ENGR				SCALE:	NONE	UNLESS OTHERWISE NOTED

SH C3 OF 23

															1	RE-ISSUED FOR BID															0	ISSUE FOR BID																							
															6/16/2016	SJM DRM HCB NA RKN CBS SM CA															6/29/2016	SJM DRM HCB NA RKN CS HCB CA																							
REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	DISPL ENGR	SCALE:	UNLESS OTHERWISE NOTED	SH C3 OF 23

Point #	Northing	Easting	Elevation
100	254561.52	2034865.50	3270.00
101	254546.78	2034876.56	3270.00
102	254552.78	2034890.90	3268.00
103	254572.59	2034878.72	3268.00
104	254591.20	2034870.27	3270.00
105	254617.91	2034879.71	3270.00
106	254625.74	2034897.87	3270.00
107	254617.91	2034894.19	3268.00
108	254628.78	2034931.37	3270.00
109	254631.00	2035000.00	3270.00
110	254618.74	2035000.00	3265.91
111	254561.33	2035000.00	3265.91
112	254546.78	2034975.40	3270.00
113	254549.02	2035000.00	3270.00
114	254558.11	2035100.00	3270.00
115	254573.43	2035100.00	3264.91
116	254618.97	2035100.00	3264.91
117	254634.24	2035100.00	3270.00
118	254637.47	2035200.00	3270.00
119	254619.21	2035200.00	3263.91
120	254585.53	2035200.00	3263.91
121	254567.20	2035200.00	3270.00
122	254619.35	2035227.72	3263.64
123	254638.31	2035225.87	3270.00
124	254650.42	2035300.00	3270.00
125	254628.88	2035300.00	3262.91
126	254597.64	2035300.00	3262.91
127	254576.29	2035300.00	3270.00
128	254583.79	2035382.47	3270.00
129	254604.83	2035359.43	3262.32
130	254631.88	2035359.43	3262.32
131	254647.93	2035382.47	3270.00
132	254658.99	2035352.54	3270.00
133	254635.56	2035350.28	3262.41

- NOTES**
- REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.
 - REFER TO PLAN SHEET 66703-C8 AND C9 FOR PYRITE POND INFLUENT DIVERSION PIPE PROFILE.
 - NOTIFY WOODROW CLIFTON (DOMINION TRANSMISSION SUPERVISOR) AT (540)280-7349 TWO WEEKS PRIOR TO BEGINNING WORK IN AREA OF TOWER.
 - CONTRACTOR IS RESPONSIBLE FOR THE PROTECTION OF THE PYRITE POND DIVERSION PIPE BASED ON THE CONSTRUCTION LOADING CONDITIONS.



REVIS
 REVIS 1: REVISED REFERENCE TO TEMPORARY 6" PIPE; REMOVED REFERENCE TO SEE SHEET C8; REVISED OUTLET STRUCTURE.



Dominion POWER GENERATION ENGINEERING RICHMOND, VIRGINIA

CTRC



PYRITE POND SUBBASE PLAN
 LWSP CLOSURE & RECONSTRUCTION - PHASE 1
 MOUNT STORM POWER STATION, WEST VIRGINIA

1	RE-ISSUED FOR BID	0	ISSUED FOR BID
6/16/2016	DM LLS JNH NA RKN CBS SM	4/29/2016	DM LLS JNH NA RKN CBS CB
DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR
REV	DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	REV	DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR
DISPL ENGR	RKN	SCALE: AS NOTED	UNLESS OTHERWISE NOTED

NOTES
 1. REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.



ELEVATION	PYRITE POND CAPACITY (GAL)	PYRITE POND CAPACITY (AC FT)
3,265	2,300	0.0
3,266	29,200	0.1
3,267	89,200	0.3
3,268	195,100	0.6
3,269	360,200	1.1
3,270	577,200	1.8

**POWER GENERATION ENGINEERING
RICHMOND, VIRGINIA**

PYRITE POND BASE AND PIPING PLAN
 LWSP CLOSURE & RECONSTRUCTION – PHASE 1
 MOUNT STORM POWER STATION, WEST VIRGINIA


1 RE-ISSUED FOR BID	0 ISSUED FOR BID
6/16/2016 DM LLS JNH NA RKN CBS SM 4/29/2016 DM LLS JNH NA RKN CBS CB	6/16/2016 DM LLS JNH NA RKN CBS CB 4/29/2016 DM LLS JNH NA RKN CBS CB
REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR
DISPL ENGR RKN SCALE: AS NOTED	UNLESS OTHERWISE NOTED SH C6 OF 23

MOUNT STORM POWER STATION CLOSURE AND RECONSTRUCTION LOW VOLUME WASTE SETTLING PONDS PHASE 2 - 2017/2018 CONSTRUCTION

**PREPARED FOR: DOMINION RESOURCES SERVICES, INC.
MOUNT STORM POWER STATION
MOUNT STORM, WEST VIRGINIA**

**PREPARED BY: TRC ENGINEERS INC.
GREENVILLE, SOUTH CAROLINA**

DATE: JUNE 2016



WEST VIRGINIA

GRANT COUNTY

SITE LOCATION

1" = 600'

ISSUED FOR BID

SHEET INDEX

DRAWING NUMBER	SHEET TITLE
66703-1	TITLE SHEET
66703-2	GENERAL NOTES - CIVIL, MECHANICAL, STRUCTURAL
66703-3	GENERAL NOTES - CIVIL, MECHANICAL, STRUCTURAL
66703-4	GENERAL NOTES - STRUCTURAL
66703-5	GENERAL NOTES - STRUCTURAL
66703-C1	CIVIL STANDARD LEGEND
66703-C2	EXISTING CONDITIONS AND DEMOLITION PLAN
66703-C3	PROPOSED HYDRAULIC PROFILE
66703-C4	CONSTRUCTION EROSION AND SEDIMENTATION CONTROL PLAN
66703-C5	PYRITE POND SUBBASE PLAN
66703-C6	PYRITE POND BASE AND PIPING PLAN
66703-C7	CROSS SECTIONS PYRITE POND
66703-C8	PYRITE POND INFLUENT DIVERSION PIPE PLAN VIEW AND DETAILS
66703-C9	PYRITE POND INFLUENT DIVERSION PIPE PROFILE AND DETAILS
66703-C10	PROPOSED YARD PIPING SITE PLAN
66703-C11	GRADIENT CONTROL FORCE MAIN PLAN
66703-C12	WATER LINE & FORCE MAINS PLAN & DETAILS
66703-C13	BACKWASH PUMP FORCE MAIN PLAN & PROFILE
66703-C14	GRAVITY LINES PLAN & PROFILE
66703-C15	FILTER BUILDING CONNECTION PLAN & PROFILE
66703-C16	POND A & B EFFLUENT STA 0+00 - 1+50
66703-C17	POND A & B EFFLUENT STA 1+50 - END
66703-C18	CIVIL DETAILS
66703-C19	CIVIL DETAILS
66703-C20	CIVIL DETAILS
66703-C21	CIVIL DETAILS
66703-C22	CIVIL DETAILS
66703-C23	CIVIL DETAILS
66703-M1	GENERAL MECHANICAL NOTES
66703-MS-0	
FL-WWT-120	PROCESS FLOW DIAGRAM I
66703-MS-0	
FL-WWT-121	PROCESS FLOW DIAGRAM II
66703-M4	FILTER BUILDING EQUIPMENT PLAN VIEW @ 3253.00
66703-M5	FILTER BUILDING EQUIPMENT SECTIONS I
66703-M6	FILTER BUILDING EQUIPMENT SECTIONS II
66703-M7	FILTER BUILDING PIPING PLAN VIEW @ 3253.00
66703-M8	FILTER PIPING SECTIONS I
66703-M9	FILTER PIPING SECTIONS II
66703-M10	OUTLET STRUCTURE - PYRITE POND
66703-M11	JUNCTION BOX DETAILS
66703-M12	MISCELLANEOUS DETAILS 1
66703-M13	MISCELLANEOUS DETAILS 2
66703-M14	MISCELLANEOUS DETAILS 3
66703-M15	MISCELLANEOUS DETAILS 4
66703-SA1	STRUCTURAL/ARCHITECTURAL FILTER STRUCTURE
66703-SA2	STRUCTURAL/ARCHITECTURAL FILTER STRUCTURE
66703-SA3	STRUCTURAL/ARCHITECTURAL FILTER STRUCTURE
66703-SA4	STRUCTURAL/ARCHITECTURAL FILTER STRUCTURE
66703-SA5	STRUCTURAL/ARCHITECTURAL FILTER STRUCTURE
66703-SA6	STRUCTURAL/ARCHITECTURAL FILTER STRUCTURE
66703-SA7	STRUCTURAL/ARCHITECTURAL SECTIONS AND DETAILS
66703-SA8	STRUCTURAL/ARCHITECTURAL SECTIONS AND DETAILS
66703-S1	STRUCTURAL FILTER STRUCTURE
66703-S2	STRUCTURAL FILTER STRUCTURE
66703-S3	STRUCTURAL FILTER STRUCTURE
66703-S4	STRUCTURAL FILTER STRUCTURE
66703-S5	STRUCTURAL PYRITE POND OUTFALL
66703-S6	STRUCTURAL PYRITE POND OUTFALL
66703-S7	STRUCTURAL JUNCTION BOX A
66703-S8	STRUCTURAL JUNCTION BOX B
66703-S9	STRUCTURAL JUNCTION BOX C
66703-S10	STRUCTURAL JUNCTION BOX C
66703-S11	STRUCTURAL TYPICAL SECTIONS & DETAILS
66703-S12	STRUCTURAL TYPICAL SECTIONS & DETAILS
66703-S13	STRUCTURAL TYPICAL SECTIONS & DETAILS
66703-S14	STRUCTURAL PEDESTRIAN BRIDGE SECTIONS & DETAILS
66703-E-001	ELECTRICAL SYMBOLS AND ABBREVIATIONS
66703-E-4500	ELECTRICAL SITE PLAN
66703-E-4800	ENLARGED ELECTRICAL PLANS #1
66703-E-4801	ENLARGED ELECTRICAL PLANS #2
66703-E-0300	EXISTING PYRITE BLDG. ENLARGED ELECTRICAL PLAN
66703-E-0900	ELECTRICAL DUCT BANK AND RACEWAY ROUTING INTERIOR ELEVATIONS AT FILTER BUILDING
66703-E-4803	ELECTRICAL ONELINE DIAGRAM AND DETAILS
66703-E-1400	PYRITE BLDG. RTU MODIFICATIONS
66703-E-1401	ELECTRICAL PANEL SCHEDULES
66703-E-4805	LIGHTING AND MECHANICAL SCHEDULES
66703-E-6000	ELECTRICAL DUCT BANK SECTIONS
66703-E-4501	ELECTRICAL DETAILS
66703-E13	RACEWAY SCHEDULE
66703-E14	CABLE SCHEDULE


- NOTES**
- REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.
 - REFER TO PLAN SHEET 66703-C21 FOR NEW PIPING LAYOUTS.

STAGE VS STORAGE MATRIX

ELEVATION	POND A CAPACITY (GAL)	POND A CAPACITY (AC FT)
3,247	40,400	0.1
3,248	198,500	0.6
3,249	502,500	1.5
3,250	844,000	2.6
3,251	1,211,100	3.7
3,252	1,604,100	4.9
3,253	2,023,700	6.2
3,254	2,470,200	7.6
3,255	2,944,000	9.0
3,256	3,445,500	10.6
3,257	3,975,300	12.2

STAGE VS STORAGE MATRIX

ELEVATION	POND B CAPACITY (GAL)	POND B CAPACITY (AC FT)
3,247	43,100	0.1
3,248	207,300	0.6
3,249	507,800	1.6
3,250	846,400	2.6
3,251	1,210,400	3.7
3,252	1,600,400	4.9
3,253	2,016,700	6.2
3,254	2,460,000	7.5
3,255	2,930,600	9.0
3,256	3,429,200	10.5
3,257	3,956,100	12.1




**POWER GENERATION ENGINEERING
RICHMOND, VIRGINIA**

**OVERVIEW – PYRITE POND, PONDS A AND B
SUBGRADE PLAN**

**LWSP – PHASE 2 – 2017 & 2018 CONSTRUCTION
MOUNT STORM POWER STATION, WEST VIRGINIA**

DSGN D.MARSHALL	DSGN SUPV _____	DATE JUNE 2016	REV. 0
DRWN L. STORMER	ENGR SUPV _____	DATE _____	REV. _____
CHKD _____	PROJ ENGR _____	DRAWING NO. 66703-C6	
DISPL ENGR _____	RKN _____	SCALE: AS NOTED	UNLESS OTHERWISE NOTED



0 ISSUED FOR BID	DATE 06/06/2016	DM LLS JNH NA	RKN CBS SM BCA
REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR	REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR

Appendix B

Flood Insurance Rate Map

NOTES TO USERS

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

To obtain more detailed information in areas where **Base Flood Elevations (BFEs)** and/or **floodways** have been determined, users are encouraged to consult the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent rounded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or floodplain management.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood Insurance Study report for this jurisdiction.

Certain areas not in Special Flood Hazard Areas may be protected by **flood control structures**. Refer to Section 2.4 "Flood Protection Measures" of the Flood Insurance Study report for information on flood control structures for this jurisdiction.

The **projection** used in the preparation of this map was Universal Transverse Mercator (UTM), Zone 17. **Horizontal datum** was NAD 83, GRS80 spheroid. Differences in datum, spheroid, projection or UTM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same **vertical datum**. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1988, visit the National Geodetic Survey website at <http://www.ngs.noaa.gov/> or contact the National Geodetic Survey at the following address:

Spatial Reference System Division
National Geodetic Survey, NOAA
Silver Spring Metro Center
1315 East-West Highway
Silver Spring, Maryland 20910
(301) 713-3191

To obtain current elevation, description, and/or location information for **bench marks** shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242, or visit its website at <http://www.ngs.noaa.gov/>.

BASE MAP SOURCE: Digital data were obtained from the U.S. Census Bureau, the West Virginia Statewide Addressing and Mapping Board (WV SAMB), the WV Dept. of Environmental Protection (WV DEP), the U.S. Forest Service (USFS), and Michael Baker Jr., Inc. (Baker) Corporation boundaries and road names were obtained from Census Tiger/Line 2000 data sets. The 1:4800 scale 2003 orthophoto base map imagery was obtained from the WV SAMB, as was the orthophoto based hydrographic vector data. County boundaries were digitized by the WV DEP from the U.S. Geological Survey 1:24000 scale topographic map Digital Raster Graphics. National Forest Boundary data were created by the Monongahela National Forest Geographic Information Systems Program, (USFS) Levee data were created by Baker for The Federal Emergency Management Agency.

Based on the above mentioned digital orthophotographs, this map reflects more detailed and up-to-date **stream channel configurations** than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables (where applicable) for South Branch Potomac River in the Flood Insurance Study report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on the map.

Corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels, community map repository addresses, and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community is located.

Contact the **FEMA Map Service Center** at 1-800-358-9616 for information on available products associated with this FIRM. Available products may include previously issued Letters of Map Change, a Flood Insurance Study report, and/or digital versions of this map. The FEMA Map Service Center may also be reached by Fax at 1-800-358-9620 and its website at <http://msc.fema.gov/>.

If you have **questions about this map** or questions concerning the National Flood Insurance Program in general, please call 1-877-FEMA-MAP (1-877-336-2627) or visit the FEMA website at <http://www.fema.gov/business/nfp>.



LEGEND

- SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD**
- The 1% annual chance flood (100-year flood), also known as the base flood, is the flood that has a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Elevation is the water-surface elevation of the 1% annual chance flood.
- ZONE A** No Base Flood Elevations determined.
 - ZONE AE** Base Flood Elevations determined.
 - ZONE AH** Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations determined.
 - ZONE AO** Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determined.
 - ZONE AR** Special Flood Hazard Area formerly protected from the 1% annual chance flood by a flood control system that was subsequently decertified. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.
 - ZONE A99** Area to be protected from 1% annual chance flood by a Federal flood protection system under construction; no Base Flood Elevations determined.
 - ZONE V** Coastal flood zone with velocity hazard (wave action); no Base Flood Elevations determined.
 - ZONE VE** Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.
- FLOODWAY AREAS IN ZONE AE**
- The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free of encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.
- OTHER FLOOD AREAS**
- ZONE X** Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.
- OTHER AREAS**
- ZONE X** Areas determined to be outside the 0.2% annual chance floodplain.
 - ZONE D** Areas in which flood hazards are undetermined, but possible.
- COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS**
- OTHERWISE PROTECTED AREAS (OPAs)**
- CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.
- 1% annual chance floodplain boundary
 - 0.2% annual chance floodplain boundary
 - Floodway boundary
 - Zone D boundary
 - CBRS and OPA boundary
 - Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities.
 - Base Flood Elevation line and value; elevation in feet*
 - Base Flood Elevation value where uniform within zone; elevation in feet*
- * Referenced to the North American Vertical Datum of 1988
- (A) Cross section line
 - (2) Transect line
- 87° 07' 45", 32° 22' 30" Geographic coordinates referenced to the North American Datum of 1983 (NAD 83)
- 4276000 M 1000-meter Universal Transverse Mercator grid values, zone 17
- 600000 FT 5000-foot grid ticks; West Virginia State Plane coordinate system (FIPSZONE 4703), Lambert Conformal Conic projection
- DX5510 x Bench mark (see explanation in Notes to Users section of this FIRM panel)
- M1.5 River Mile

MAP REPOSITORY
Refer to listing of Map Repositories on Map Index.

EFFECTIVE DATE OF COUNTYWIDE FLOOD INSURANCE RATE MAP
SEPTEMBER 2, 2009

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

For community map revision history prior to countywide mapping, refer to the Community Map History table located in the Flood Insurance Study report for this jurisdiction.

To determine if flood insurance is available in this community, contact your insurance agent or call the National Flood Insurance Program at 1-800-638-6620.

MAP SCALE 1" = 1000'

500 0 1000 2000 FEET

300 0 300 600 METERS

NATIONAL FLOOD INSURANCE PROGRAM

PANEL 0135F

FIRM
FLOOD INSURANCE RATE MAP

GRANT COUNTY, WEST VIRGINIA AND INCORPORATED AREAS

PANEL 135 OF 425
(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

COMMUNITY	NUMBER	PANEL	SUFFIX
GRANT COUNTY	540038	0135	F

Notice to User: The Map Number shown below should be used when placing map orders. The Community Number shown above should be used on insurance applications for the subject community.

MAP NUMBER
54023C0135F

EFFECTIVE DATE
SEPTEMBER 2, 2009

Federal Emergency Management Agency

Appendix C

Storm Water Calculations

Table of Contents

- Storm Water Capacity of the Existing LVWSP
- Storm Water Capacity of Reconstructed Ponds A and B

Storm Water Capacity of the Existing LVWSP



PROJECT / LOCATION: Mount Storm Power Station - Mount Storm, West Virginia - LVWSP		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of Existing Ponds A through D		230765.0000
PREPARED BY: S. Sellner	DATE: 8/15/2016	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 8/19/2016	REVISION <input type="checkbox"/>

Purpose: Determine if there is sufficient capacity to contain the runoff volume collected in the LVWSP from the 100 year, 24 hour storm event for the existing LVSWP (Ponds A, B, C, and D)

Methodology: Calculate inflow for the 100 year, 24 hour storm event. Determine the available capacity for the volume of storm water by estimating additional flow that can be provided from the outlet and available freeboard capacity of Ponds A, B, C, and D.

INFLOWS

1.) Determine storm water inflows into the retrofitted Pyrite Pond

- Station storm water flows into Pyrite Pond (Refer to Attached Figure).
- The drainage area is approximately 75.4 acres.

- Volume of runoff determined by HydroCAD output (See Attached). This output was performed based upon values determined in the storm water analysis

$$V_{\text{Runoff}} = \text{Volume of Runoff (acre feet) for the 100 year, 24 hour storm event}$$

$$V_{\text{Runoff}} = 31.0 \text{ acre feet}$$

2.) Determine storm water inflow into Ponds A, B, C, and D

- Effective area of storm water based upon midpoint of outside berms from CAD drawing.
- It is assumed that there is no infiltration

$$V_{\text{Pond Inflow}} = iA$$

$$V = \text{Storm Water Inflow to Pyrite Pond}$$

$$i = \text{Precipitation Frequency (inches/day) 100 year, 24 hour storm event}$$

$$A = \text{Area (acre)}$$

$$i = 6.19 \text{ inches/day}$$

$$A = 7.5 \text{ acres}$$

$$V_{\text{Pond Inflow}} = 46.4 \text{ acre inches}$$

$$V_{\text{Pond Inflow}} = 3.87 \text{ acre feet}$$

$$V_{\text{Inflow}} = \text{Volume of Total Inflows}$$

$$V_{\text{Inflow}} = V_{\text{Runoff}} + V_{\text{Pond Inflow}}$$

$$V_{\text{Inflow}} = 34.9 \text{ acre feet}$$

Note:

Areas and volumes are from the Civil 3D existing conditions model, refer to attached sheets

Design storm data from NOAA, refer to attached sheets



PROJECT / LOCATION: Mount Storm Power Station - Mount Storm, West Virginia - LVWSP		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of Existing Ponds A through D		230765.0000
PREPARED BY: S. Sellner	DATE: 8/15/2016	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 8/19/2016	REVISION <input type="checkbox"/>

OUTFLOWS

3.) Determine volume out of the LVWSP outlet - Volume of flow based on the difference between the max flow and normal operating flow. This difference provides the additional outflow capacity from the LVWSP that is available during a storm event. The normal operational flow is based on instantaneous readings and assumed to equal the average + 2 standard deviations

- Volumes based upon Settling Capacity Analysis calculation performed on 9/23/2015, see attachments
- Maximum outflow rate assumed to be 26 million gallons per day (MGD)

$$Q_{\text{Outflow}} = Q_{\text{Max}} - \text{Ave.} + 2\sigma$$

$$Q_{\text{Outflow}} = \text{Available Outflow Rate (MGD)}$$

$$\text{Ave.} + 2\sigma = \text{Average} + 2 \text{ Standard Deviations Flow Rate (MGD)}$$

$$Q_{\text{Max}} = \text{Maximum Outflow Rate (MGD)}$$

$$\text{Ave.} + 2\sigma = 18 \quad \text{MGD}$$

$$Q_{\text{Max}} = 26 \quad \text{MGD}$$

$$Q_{\text{Outflow}} = 8 \quad \text{MGD}$$

- Convert available flow rate to available volume for outflow (Assuming flow for 24 hours - 1 day)

$$V_{\text{Outflow}} = Q_{\text{Outflow}} * \text{Days of Flow}$$

- Convert million gallons per day (MGD) to Acre-Feet

$$V_{\text{Outflow}} = \text{Available Outflow Volume}$$

$$Q_{\text{Outflow}} = \text{Available Outflow Rate}$$

$$V_{\text{Outflow}} = 24.5 \quad \text{acre feet}$$

AVAILABLE FREEBOARD

4.) Determine volume of available freeboard in the existing LVSWP (Pond A, B, C, and D)

- Pond Elevations and Volumes determined by Civil 3D, see attached
- Top of operating water level based on station measurements

Pond Elevations (feet NAVD88)

	Pond A	Pond B	Pond C	Pond D
Top of Berm Elevation	3,260	3,260	3,254	3,254
Top of Water Elevation	3,255	3,255	3,252	3,252



PROJECT / LOCATION: Mount Storm Power Station - Mount Storm, West Virginia - LVWSP		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of Existing Ponds A through D		230765.0000
PREPARED BY: S. Sellner	DATE: 8/15/2016	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 8/19/2016	REVISION <input type="checkbox"/>

Pond Capacities

	Pond A	Pond B	Pond C	Pond D
Top of Berm (cubic yards)	20,670	28,120	26,418	27,893
Top of Water (cubic yards)	11,700	18,365	22,080	23,110

Freeboard Volumes (S_{FB}) = Top of Berm Volume (cy) - Bottom of Pond Volume (cy)

S_{FB-A}	=	8,970	cy
S_{FB-B}	=	9,755	cy
S_{FB-C}	=	4,338	cy
S_{FB-D}	=	4,783	cy

Total Storage of Existing Freeboard = $S_{FB-A} + S_{FB-B} + S_{FB-C} + S_{FB-D}$

S_{FB}	=	27,846	cy
S_{FB}	=	17	acre feet

5.) Compare the calculated inflow volumes vs. the outflow volumes considering the volume from the Freeboard Capacity



-Determine the Freeboard Volume Capacity compare to the flow difference

$$V_{\text{Inflow}} < V_{\text{outflow}} + S_{\text{FB}}$$

V_{Inflow}	=	34.9	acre feet
$V_{\text{outflow}} + S_{\text{FB}}$	=	41.8	acre feet

34.9	<	41.8	OK
------	---	------	----

Conclusion: Based upon the inflow, outflow, and freeboard capacity of the existing LVWSP, the system has sufficient capacity to accommodate the runoff associated with a 100 year, 24 hour storm event.



PLOT DATE: December 11, 2015 12:00 PM - LAYOUT: 22324L
 DRAWING NAME: P:\Island\Dominion\Storm\Stormwater\X\Drainage\Areas.dwg

PROJECT: DOMINION POWER MT. STORM POWER STATION MT. STORM, WV CIVIL DESIGN		
TITLE: STORM WATER RUNOFF INFLOWING TO PYRITE POND		
DRAWN BY: E. OLSON	PROJ. NO.: 230765	FIGURE 01
CHECKED BY: D. ENGSTROM		
APPROVED BY: J. HOTSTREAM		
DATE: 12/10/2015		
		708 Heartland Trail Suite 3000 Madison, WI 53717 Phone: 608.826.3600
FILE NO.:	X-Drainage Areas.dwg	

Pyrite Pond Bypass SW Model

Prepared by TRC

HydroCAD® 10.00 s/n 08043 © 2013 HydroCAD Software Solutions LLC

Printed 12/11/2015

Page 2

Area Listing (all nodes)

Area (acres)	CN	Description (subcatchment-numbers)
11.341	84	50-75% Grass cover, Fair, HSG D (S-3, S-4, S-5, S-8)
0.746	98	Paved parking, HSG D (S-3, S-5)
60.862	93	Urban industrial, 72% imp, HSG D (S-1, S-7)
2.499	98	Water Surface, HSG D (S-2, S-6)
75.448	92	TOTAL AREA ← Calculation Step 1

MT Storm

Prepared by TRC

HydroCAD® 10.00-17 s/n 08043 © 2016 HydroCAD Software Solutions LLC

Type II 24-hr Rainfall=6.19"

Printed 8/18/2016

Page 1

Summary for Subcatchment 1S: Drainage Area to Ponds

[46] Hint: Tc=0 (Instant runoff peak depends on dt)

Runoff = 717.06 cfs @ 11.89 hrs, Volume= 30.960 af, Depth> 4.92"


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 5.00-20.00 hrs, dt= 0.05 hrs
Type II 24-hr Rainfall=6.19"

Calculation Step 1

Area (ac)	CN	Description
* 75.450	92	Weighted Average from Permit
75.450		100.00% Pervious Area

Subcatchment 1S: Drainage Area to Ponds

Hydrograph



**NOAA Atlas 14, Volume 2, Version 3 MOUNT
STORM**



Station ID: 46-6293
Location name: Mount Storm, West Virginia, US*
Latitude: 39.2833°, Longitude: -79.2333°
Elevation:
Elevation (station metadata): 2851 ft*
 * source: Google Maps



POINT PRECIPITATION FREQUENCY ESTIMATES

G.M. Bonnin, D. Martin, B. Lin, T. Parzybok, M.Yekta, and D. Riley

NOAA, National Weather Service, Silver Spring, Maryland


[PF tabular](#) | [PF graphical](#) | [Maps & aerials](#)

PF tabular

PDS-based point precipitation frequency estimates with 90% confidence intervals (in inches)¹										
Duration	Average recurrence interval (years)									
	1	2	5	10	25	50	100	200	500	1000
5-min	0.301 (0.268-0.339)	0.355 (0.314-0.400)	0.427 (0.378-0.480)	0.488 (0.431-0.549)	0.570 (0.500-0.637)	0.639 (0.559-0.713)	0.708 (0.616-0.790)	0.785 (0.678-0.875)	0.893 (0.764-0.993)	0.981 (0.832-1.09)
10-min	0.469 (0.417-0.527)	0.554 (0.490-0.626)	0.664 (0.587-0.747)	0.755 (0.666-0.848)	0.872 (0.766-0.975)	0.970 (0.848-1.08)	1.07 (0.929-1.19)	1.17 (1.01-1.31)	1.31 (1.13-1.46)	1.44 (1.22-1.60)
15-min	0.575 (0.511-0.646)	0.678 (0.599-0.765)	0.816 (0.722-0.918)	0.929 (0.820-1.04)	1.08 (0.946-1.21)	1.20 (1.05-1.34)	1.33 (1.15-1.48)	1.46 (1.26-1.62)	1.64 (1.40-1.82)	1.79 (1.52-2.00)
30-min	0.761 (0.676-0.856)	0.908 (0.803-1.02)	1.12 (0.989-1.26)	1.29 (1.14-1.45)	1.52 (1.34-1.70)	1.72 (1.50-1.92)	1.92 (1.67-2.14)	2.13 (1.84-2.38)	2.43 (2.08-2.71)	2.69 (2.28-3.00)
60-min	0.930 (0.827-1.05)	1.11 (0.986-1.26)	1.40 (1.24-1.58)	1.64 (1.45-1.85)	1.98 (1.74-2.21)	2.27 (1.98-2.53)	2.57 (2.23-2.86)	2.90 (2.50-3.23)	3.37 (2.88-3.75)	3.79 (3.21-4.22)
2-hr	1.10 (0.976-1.24)	1.32 (1.17-1.49)	1.66 (1.47-1.87)	1.97 (1.74-2.20)	2.39 (2.10-2.66)	2.77 (2.41-3.08)	3.17 (2.75-3.52)	3.61 (3.11-4.00)	4.26 (3.63-4.70)	4.84 (4.08-5.34)
3-hr	1.19 (1.05-1.34)	1.42 (1.26-1.60)	1.77 (1.57-2.00)	2.09 (1.85-2.35)	2.54 (2.23-2.85)	2.94 (2.56-3.28)	3.37 (2.92-3.76)	3.85 (3.32-4.2)	4.56 (3.91-5.35)	5.20 (4.57-6.30)
6-hr	1.48 (1.28-1.73)	1.76 (1.53-2.06)	2.17 (1.88-2.53)	2.55 (2.20-2.96)	3.08 (2.64-3.57)	3.55 (3.04-4.10)	4.07 (3.45-4.69)	4.64 (3.91-5.35)	5.48 (4.57-6.30)	6.24 (5.14-7.16)
12-hr	1.83 (1.60-2.15)	2.17 (1.90-2.54)	2.66 (2.33-3.11)	3.12 (2.72-3.64)	3.79 (3.27-4.40)	4.38 (3.76-5.07)	5.03 (4.28-5.87)	5.76 (4.85-6.64)	6.86 (5.69-7.89)	7.86 (6.44-9.02)
24-hr	2.18 (1.96-2.45)	2.61 (2.34-2.94)	3.25 (2.91-3.65)	3.80 (3.39-4.26)	4.63 (4.09-5.18)	5.37 (4.69-6.0)	6.19 (5.33-6.93)	7.11 (6.05-7.97)	8.54 (7.09-9.61)	9.78 (7.98-11.0)
2-day	2.55 (2.32-2.83)	3.05 (2.78-3.38)	3.79 (3.44-4.20)	4.42 (4.00-4.90)	5.39 (4.82-5.97)	6.24 (5.53-6.91)	7.19 (6.30-7.97)	8.26 (7.13-9.18)	9.92 (8.39-11.1)	11.4 (9.45-12.8)
3-day	2.77 (2.56-3.03)	3.31 (3.05-3.61)	4.06 (3.74-4.43)	4.70 (4.31-5.13)	5.64 (5.12-6.16)	6.45 (5.79-7.06)	7.33 (6.51-8.06)	8.30 (7.26-9.23)	9.97 (8.40-11.1)	11.4 (9.49-12.8)
4-day	3.00 (2.80-3.23)	3.57 (3.33-3.85)	4.34 (4.04-4.67)	4.98 (4.62-5.36)	5.89 (5.42-6.36)	6.66 (6.06-7.22)	7.46 (6.72-8.15)	8.33 (7.39-9.27)	10.0 (8.41-11.2)	11.5 (9.54-12.9)
7-day	3.49 (3.27-3.74)	4.14 (3.87-4.44)	4.96 (4.63-5.32)	5.63 (5.24-6.05)	6.57 (6.06-7.07)	7.32 (6.70-7.91)	8.09 (7.34-8.80)	8.89 (7.98-9.75)	10.1 (8.82-11.3)	11.6 (9.63-13.0)
10-day	4.03 (3.80-4.29)	4.75 (4.48-5.06)	5.60 (5.28-5.96)	6.28 (5.90-6.68)	7.19 (6.70-7.67)	7.89 (7.32-8.45)	8.60 (7.91-9.26)	9.32 (8.49-10.1)	10.3 (9.26-11.4)	11.7 (9.91-13.1)
20-day	5.65 (5.37-5.96)	6.61 (6.28-6.98)	7.60 (7.22-8.04)	8.41 (7.96-8.90)	9.47 (8.92-10.0)	10.3 (9.63-11.0)	11.1 (10.3-11.9)	11.9 (11.0-12.8)	12.9 (11.8-14.1)	13.7 (12.3-15.0)
30-day	7.11 (6.78-7.46)	8.28 (7.90-8.71)	9.40 (8.95-9.89)	10.3 (9.78-10.8)	11.4 (10.8-12.0)	12.3 (11.6-13.0)	13.1 (12.3-13.9)	13.9 (13.0-14.8)	14.9 (13.8-16.0)	15.6 (14.3-16.9)
45-day	9.09 (8.70-9.50)	10.5 (10.1-11.0)	11.8 (11.3-12.4)	12.8 (12.3-13.5)	14.1 (13.4-14.8)	15.1 (14.3-15.9)	15.9 (15.1-16.9)	16.8 (15.8-17.8)	17.8 (16.6-19.0)	18.5 (17.1-19.9)
60-day	10.9 (10.5-11.4)	12.7 (12.2-13.3)	14.1 (13.5-14.8)	15.3 (14.6-16.0)	16.7 (15.9-17.5)	17.7 (16.8-18.7)	18.7 (17.7-19.7)	19.6 (18.4-20.8)	20.6 (19.3-22.0)	21.4 (19.9-22.9)


Calculation Step 2

¹ Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS). Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values. Please refer to NOAA Atlas 14 document for more information.



- LEGEND**
- SECTION 704 CLASS 3 AGGREGATE OVER SECTION 704 CLASS 2 AGGREGATE (ACCESS ROAD)
 - RIPRAP D₅₀ = 8" OVER DENSE AGGREGATE BASE SECTION 704, CLASS 10.
 - 6" THICK COVER GRAVEL SECTION 703 COURSE AGGREGATE GRADATION #24 OVER SEPARATION GEOTEXTILE.
 - EROSION CONTROL MAT, TOPSOIL, AND VEGETATION
 - 6" TOPSOIL AND VEGETATION
 - TEMPORARY ACCESS ROAD SECTION 704 CLASS 3 AGGREGATE (8" THICK) OVER SEPARATION GEOTEXTILE
 - LIMITS OF DISTURBANCE FOR AREA FLOWING TO PONDS (2.4 ACRES) (COVERED UNDER CURRENTLY ACTIVE INDIVIDUAL NPDGS PERMIT NO. WV000525)
 - LIMITS OF DISTURBANCE FOR AREA NOT FLOWING TO PONDS (1.7 ACRES) (COVERED UNDER GENERAL NPDES PERMIT NO. WV0115924)
 - SUPER SILT FENCE
- NOTES**
- REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.

Calculation Step 2
 325,890 square feet
 7.5 acres



REVISIONS											
REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	I&C ENGR
1		RE-ISSUED FOR BID									
0		ISSUED FOR BID									
6/16/2016	DM	LLS	JNH	NA	RKN	CBS	SM				
4/29/2016	DM	LLS	JNH	NA	RKN	CBS	CB				

CHKD	JHN	PROJ ENGR	DATE	JUNE 2016	DISPL ENGR	RKN
DRWN L.	STORMER	ENGR SUPV	DATE	JUNE 2016	DISPL ENGR	RKN
DATE	JUNE 2016	DATE	JUNE 2016	DATE	JUNE 2016	DATE
DATE	JUNE 2016	DATE	JUNE 2016	DATE	JUNE 2016	DATE
SCALE: AS NOTED			UNLESS OTHERWISE NOTED			SH C4 OF 23

Dominion **CTR**

POWER GENERATION ENGINEERING
 RICHMOND, VIRGINIA

CONSTRUCTION EROSION AND SEDIMENTATION
 CONTROL PLAN

LWSP CLOSURE & RECONSTRUCTION – PHASE 1
 MOUNT STORM POWER STATION, WEST VIRGINIA



PROJECT / PROPOSAL NAME / LOCATION:	PROJECT / PROPOSAL NO.	FINAL
Mount Storm - Settling Capacity Analysis	230765.0000 Phase 4	
PREPARED BY: D. Engstrom	DATE: 9/21/2015	REVISION
CHECKED BY: J. Hotstream	DATE: 9/23/2015	10/28/2015

SUMMARY OF FLOW DATA AND CALCULATIONS

Method:

Flow data into the primary settling ponds (Ponds A and B) were not available to estimate treatability of influent. Flow ranges are estimated based on monthly monitoring of the permitted outfall to Mt. Storm Lake since 2001 and calculated flows from the weir in the Pond A/B distribution box.

Data from Monitoring Point 401 represents the outfall after Ponds C and D. It is assumed that this flow is equal to the inflow to the ponds. Calculated influent flow values are based on water heights over the weir in the Pond A/B distribution box obtained on 8/24, 8/25, and 8/27/15. Several calculated flows are plotted on Figure 1

Figure 1:




Table 1. Statistical summary of the Outfall 401 flow data.

STATISTICAL PARAMETER	FLOW (MGD)
Average	10.6
Maximum	28.3
Minimum	2.8
Median	10.3
Standard Deviation	3.7
Lower Quartile	8.04
Upper Quartile	13.5
Average Plus Two Standard Deviations	18.0
Adjusted Maximum	28.3

Calculation Step 3.

Discussion:

Fifteen years of data from Outfall 401 provides maximum flow of 28.3 MGD, a minimum flow of 2.8 MGD, and an average flow of 10.6 MGD. These data from Outfall 401 are normally distributed. Therefore considering a value of the mean and 2 standard deviations, 18 MGD, captures 95%+ of the population. Recent data, from 2010 to present, suggest maximum flows of 15 MGD. Comparing this analysis to field measurements at the weir support a maximum flow value of 18 MGD (27.85 cfs).

Cut/Fill Report

Generated: 2016-08-19 09:56:48

By user: LStormer

J:\Dominion Resources\Mt. Storm\230765 - Liner Construction\000004

Drawing: \DTM\Volumes\J:\Dominion Resources\Mt. Storm\230765 - Liner Construction\000004
 \DTM\Volumes\Pond Hydraulic Height Volumes.dwg

Calculation Step 4

Volume Summary							
Name	Type	Cut Factor	Fill Factor	2d Area (Sq. Ft.)	Cut (Cu. Yd.)	Fill (Cu. Yd.)	Net (Cu. Yd.)
Pond A Existing to Elev 3255	full	1.000	1.000	43601.65	0.00	11692.46	11692.46<Fill>
Pond B Existing to Elev 3255	full	1.000	1.000	48576.36	0.00	18361.99	18361.99<Fill>
Pond C Existing to Elev 3252	full	1.000	1.000	56818.44	0.00	22078.87	22078.87<Fill>
Pond D Existing to Elev 3252	full	1.000	1.000	62375.13	0.00	23108.98	23108.98<Fill>

Totals				
	2d Area (Sq. Ft.)	Cut (Cu. Yd.)	Fill (Cu. Yd.)	Net (Cu. Yd.)
Total	211371.58	0.00	75242.30	75242.30<Fill>

* Value adjusted by cut or fill factor other than 1.0

Cut/Fill Report

Generated: 2016-08-18 14:25:17

By user: LStormer

J:\Dominion Resources\Mt. Storm\230765 - Liner Construction\000004

Drawing: \DTM\Volumes\J:\Dominion Resources\Mt. Storm\230765 - Liner Construction\000004
 \DTM\Volumes\Pond Hydraulic Height Volumes.dwg

Volume Summary							
Name	Type	Cut Factor	Fill Factor	2d Area (Sq. Ft.)	Cut (Cu. Yd.)	Fill (Cu. Yd.)	Net (Cu. Yd.)
Pond C Existing to Elev 3254	full	1.000	1.000	60355.76 Calculation Step 4	0.00	26417.68	26417.68<Fill>
Pond D Existing to Elev 3254	full	1.000	1.000	66865.99	0.00	27893.24	27893.24<Fill>
Pond A Existing to Elev 3260	full	1.000	1.000	53379.92	0.00	20670.05	20670.05<Fill>

Pond B Existing to Elev 3260	full	1.000	1.000	56868.31	0.00	28119.69	28119.69<Fill>
---------------------------------------	------	-------	-------	----------	------	----------	----------------

Calculation Step 4

Totals				
	2d Area (Sq. Ft.)	Cut (Cu. Yd.)	Fill (Cu. Yd.)	Net (Cu. Yd.)
Total	452032.86	11.85	144860.13	144848.27<Fill>

* Value adjusted by cut or fill factor other than 1.0

Storm Water Capacity of Reconstructed Ponds A and B



PROJECT / LOCATION: Mount Storm Power Station - Mount Storm, West Virginia - LVWSP		PROJECT / PROPOSAL NO.	
SUBJECT: Storm Water Capacity of Reconstructed Pond A and Pond B		230765.0000	
PREPARED BY: S. Sellner	DATE: 8/18/2016	FINAL	<input type="checkbox"/>
CHECKED BY: J. Hotstream	DATE: 8/18/2016	REVISION	<input type="checkbox"/>

Purpose: Determine if there is sufficient capacity to contain the runoff volume collected in the LVWSP from the 100 year, 24 hour storm event for the reconstructed LVWSP (Pond A and Pond B)

Methodology: Calculate inflow for the 100 year, 24 hour storm event. Determine the available capacity for the volume of storm water by estimating additional flow that can be provided from the outlet and available freeboard capacity of the reconstructed Ponds A and B.

INFLOWS

1.) Determine storm water inflows into the retrofitted Pyrite Pond

- Site storm water flows into Pyrite Pond (Refer to Attached Figure).
- The drainage area is approximately 75.4 acres.
- Volume of runoff determined by HydroCAD output (See Attached). This output was performed based upon values determined in the storm water analysis

$$V_{\text{Runoff}} = \text{Volume of Runoff (acre feet)}$$

$$V_{\text{Runoff}} = 31.0 \text{ acre feet}$$

2.) Determine storm water inflow into Pond A and Pond B

- Effective area of storm water based upon midpoint of outside berms from CAD drawing. Runoff coefficient assumed to be 1.0 as the entire area flows inward and there is no infiltration

$$V = iA$$

$$V = \text{Storm Water Inflow to Pyrite Pond}$$

$$i = \text{Precipitation Frequency (inches/day) 100 year, 24 hour storm event}$$

$$A = \text{Area (acre)}$$

$$i = 6.19 \text{ inches/day}$$

$$A = 5.5 \text{ acres}$$

$$V_{\text{Pond Inflow}} = 34.05 \text{ acre inches}$$

$$V_{\text{Pond Inflow}} = 2.84 \text{ acre feet}$$

$$V_{\text{Inflow}} = \text{Volume of Total Inflows}$$

$$V_{\text{Inflow}} = V_{\text{Runoff}} + V_{\text{Pond Inflow}}$$

$$V_{\text{Inflow}} = 33.8 \text{ acre feet}$$

Note:

Areas and volumes are from the Civil 3D pond reconstruction model, refer to attached sheets

Design storm data from NOAA, refer to attached sheets



PROJECT / LOCATION: Mount Storm Power Station - Mount Storm, West Virginia - LVWSP		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of Reconstructed Pond A and Pond B		230765.0000
PREPARED BY: S. Sellner	DATE: 8/18/2016	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	CHECKED BY: J. Hotstream	REVISION <input type="checkbox"/>

OUTFLOWS

3.) Determine volume out of the LVWSP outlet - Volume of flow based on the difference between the max flow and normal operating flow. This difference provides the additional outflow capacity from the LVWSP that is available during a storm event. The normal operational flow is based on instantaneous readings and assumed to equal the average + 2 standard deviations

- Volumes based upon Settling Capacity Analysis calculation performed on 9/23/2015, see attachments
- Maximum design outflow rate is 26 million gallons per day (MGD)

$$Q_{\text{Outflow}} = Q_{\text{Max}} - \text{Ave.} + 2\sigma$$

$$Q_{\text{Outflow}} = \text{Available Outflow Rate (MGD)}$$

$$\text{Ave.} + 2\sigma = \text{Average} + 2 \text{ Standard Deviations Flow Rate (MGD)}$$

$$Q_{\text{Max}} = \text{Maximum Outflow Rate (MGD)}$$

$$\text{Ave.} + 2\sigma = 18 \text{ MGD}$$

$$Q_{\text{Max}} = 26 \text{ MGD}$$

$$Q_{\text{Outflow}} = 8 \text{ MGD}$$

- Convert available flow rate to available volume for Outflows (Assuming flow for 1 day)

$$V_{\text{Outflow}} = Q_{\text{Outflow}} * \text{Days of Flow}$$

- Convert million gallons per day (MGD) to Acre-Feet

$$V_{\text{Outflow}} = \text{Available Outflow Volume}$$

$$Q_{\text{Outflow}} = \text{Available Outflow Rate}$$

$$V_{\text{Outflow}} = 24.5 \text{ acre feet}$$

AVAILABLE FREEBOARD

4.) Determine volume of available freeboard in the reconstructed LVSWP (Pond A and B)

- Pond Elevations and Volumes determined by Civil 3D, see attachments
- Top of operating water level based on design maximum levels.

Pond Elevations (feet NAVD88)

	Pond A	Pond B
Top of Berm Elevation	3,260	3,260
Top of Water Elevation	3,255	3,255



PROJECT / LOCATION: Mount Storm Power Station - Mount Storm, West Virginia - LVWSP		PROJECT / PROPOSAL NO.
SUBJECT: Storm Water Capacity of Reconstructed Pond A and Pond B		230765.0000
PREPARED BY: S. Sellner	DATE: 8/18/2016	FINAL <input type="checkbox"/>
CHECKED BY: J. Hotstream	CHECKED BY: J. Hotst	REVISION <input type="checkbox"/>

Pond Capacities

	Pond A	Pond B
Top of Berm (cubic yards)	35,559	35,358
Top of Water (cubic yards)	14,577	14,511

Freeboard Volumes (S_{FB}) = Top of Berm Volume (cy) - Top of Water Volume (cy)

$$S_{FB-A} = 20,982 \text{ cy}$$

$$S_{FB-B} = 20,847 \text{ cy}$$

Total Storage of Existing Freeboard = $S_{FB-A} + S_{FB-B} + S_{FB-C} + S_{FB-D}$

$$S_{FB} = 41,829 \text{ cy}$$

$$S_{FB} = 26 \text{ acre feet}$$

5.) Compare the calculated inflow volumes vs. the outflow volumes considering the volume from the Freeboard Capacity

-Determine the Freeboard Volume Capacity compare to the flow difference



$$V_{\text{Inflow}} < V_{\text{outflow}} + S_{FB}$$

$$V_{\text{Inflow}} = 33.8 \text{ acre feet}$$

$$V_{\text{outflow}} + S_{FB} = 50.4 \text{ acre feet}$$

$$33.8 < 50.4 \quad \text{OK}$$

Conclusion: Based upon the inflow, outflow, and freeboard capacity of the reconstructed LVWSP, the system has sufficient capacity to accommodate the runoff associated with a 100 year, 24 hour storm event.



PLOT DATE: December 11, 2015 12:00 PM - LAYOUT: 22324L
 DRAWING NAME: P:\Island\Dominion\Storm\Stormwater\X\Drainage\Areas.dwg

PROJECT: DOMINION POWER MT. STORM POWER STATION MT. STORM, WV CIVIL DESIGN		
TITLE: STORM WATER RUNOFF INFLOWING TO PYRITE POND		
DRAWN BY: E. OLSON	PROJ. NO.: 230765	FIGURE 01
CHECKED BY: D. ENGSTROM		
APPROVED BY: J. HOTSTREAM		
DATE: 12/10/2015		
		708 Heartland Trail Suite 3000 Madison, WI 53717 Phone: 608.826.3600
FILE NO.:	X-Drainage Areas.dwg	

Pyrite Pond Bypass SW Model

Prepared by TRC

HydroCAD® 10.00 s/n 08043 © 2013 HydroCAD Software Solutions LLC

Printed 12/11/2015

Page 2

Area Listing (all nodes)

Area (acres)	CN	Description (subcatchment-numbers)
11.341	84	50-75% Grass cover, Fair, HSG D (S-3, S-4, S-5, S-8)
0.746	98	Paved parking, HSG D (S-3, S-5)
60.862	93	Urban industrial, 72% imp, HSG D (S-1, S-7)
2.499	98	Water Surface, HSG D (S-2, S-6)
75.448	92	TOTAL AREA ← Calculation Step 1

MT Storm

Prepared by TRC

HydroCAD® 10.00-17 s/n 08043 © 2016 HydroCAD Software Solutions LLC

Type II 24-hr Rainfall=6.19"

Printed 8/18/2016

Page 1

Summary for Subcatchment 1S: Drainage Area to Ponds

[46] Hint: Tc=0 (Instant runoff peak depends on dt)

Runoff = 717.06 cfs @ 11.89 hrs, Volume= 30.960 af, Depth> 4.92"


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 5.00-20.00 hrs, dt= 0.05 hrs
Type II 24-hr Rainfall=6.19"


Calculation Step 1

Area (ac)	CN	Description
* 75.450	92	Weighted Average from Permit
75.450		100.00% Pervious Area

Subcatchment 1S: Drainage Area to Ponds

Hydrograph






Calculation Step 2
 Area = 237,230
 square feet
 Area = 5.5 acres

- LEGEND**
- SECTION 704 CLASS 3 AGGREGATE OVER SECTION 704 CLASS 2 AGGREGATE (ACCESS ROAD)
 - RIPRAP D₅₀ = 8" OVER DENSE AGGREGATE BASE SECTION 704, CLASS 10.
 - 6" THICK COVER GRAVEL SECTION 703 COURSE AGGREGATE GRADATION #24 OVER SEPARATION GEOTEXTILE.
 - DENSE AGGREGATE BASE (SECTION 704, CLASS 10)
 - 6" TOPSOIL AND VEGETATION
 - LIMITS OF DISTURBANCE FOR AREA FLOWING TO PONDS (6.0 ACRES) (COVERED UNDER CURRENTLY ACTIVE INDIVIDUAL NPDES PERMIT NO. WV000525)
 - LIMITS OF DISTURBANCE FOR AREA NOT FLOWING TO PONDS (7.7 ACRES) (COVERED UNDER GENERAL NPDES PERMIT NO. WV0115924)

NOTES

- REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.



**POWER GENERATION ENGINEERING
 RICHMOND, VIRGINIA**

**CONSTRUCTION EROSION AND SEDIMENTATION
 CONTROL PLAN**

**LVWSP – PHASE 2 – 2017 & 2018 CONSTRUCTION
 MOUNT STORM POWER STATION, WEST VIRGINIA**

0 ISSUED FOR BID												DATE: JUNE 2016	
DGN L. STORMER												DGN SPEC FOR FILE VERIFICATION	
CHKD JNH												DRAWING NO. 66703-C5	
DISPL ENGR												REV. 0	
SCALE: AS NOTED												UNLESS OTHERWISE NOTED	
SH C5 OF 71													

REV DATE DSGN DRWN CHKD DSGN SUPV PROJ ENGR CIVIL ENGR ELEC ENGR MECH ENGR ARCH E.M. ENGR I&C ENGR
 06 06 2016 DM LLS JNH NA RKN CBS SM BCA JNH PROJ ENGR
 06 06 2016 DM LLS JNH NA RKN CBS SM BCA JNH PROJ ENGR

**NOAA Atlas 14, Volume 2, Version 3 MOUNT
STORM**



Station ID: 46-6293
Location name: Mount Storm, West Virginia, US*
Latitude: 39.2833°, Longitude: -79.2333°
Elevation:
Elevation (station metadata): 2851 ft*
* source: Google Maps



POINT PRECIPITATION FREQUENCY ESTIMATES

G.M. Bonnin, D. Martin, B. Lin, T. Parzybok, M.Yekta, and D. Riley

NOAA, National Weather Service, Silver Spring, Maryland

[PF tabular](#) | [PF graphical](#) | [Maps & aeriels](#)

PF tabular

PDS-based point precipitation frequency estimates with 90% confidence intervals (in inches)¹										
Duration	Average recurrence interval (years)									
	1	2	5	10	25	50	100	200	500	1000
5-min	0.301 (0.268-0.339)	0.355 (0.314-0.400)	0.427 (0.378-0.480)	0.488 (0.431-0.549)	0.570 (0.500-0.637)	0.639 (0.559-0.713)	0.708 (0.616-0.790)	0.785 (0.678-0.875)	0.893 (0.764-0.993)	0.981 (0.832-1.09)
10-min	0.469 (0.417-0.527)	0.554 (0.490-0.626)	0.664 (0.587-0.747)	0.755 (0.666-0.848)	0.872 (0.766-0.975)	0.970 (0.848-1.08)	1.07 (0.929-1.19)	1.17 (1.01-1.31)	1.31 (1.13-1.46)	1.44 (1.22-1.60)
15-min	0.575 (0.511-0.646)	0.678 (0.599-0.765)	0.816 (0.722-0.918)	0.929 (0.820-1.04)	1.08 (0.946-1.21)	1.20 (1.05-1.34)	1.33 (1.15-1.48)	1.46 (1.26-1.62)	1.64 (1.40-1.82)	1.79 (1.52-2.00)
30-min	0.761 (0.676-0.856)	0.908 (0.803-1.02)	1.12 (0.989-1.26)	1.29 (1.14-1.45)	1.52 (1.34-1.70)	1.72 (1.50-1.92)	1.92 (1.67-2.14)	2.13 (1.84-2.38)	2.43 (2.08-2.71)	2.69 (2.28-3.00)
60-min	0.930 (0.827-1.05)	1.11 (0.986-1.26)	1.40 (1.24-1.58)	1.64 (1.45-1.85)	1.98 (1.74-2.21)	2.27 (1.98-2.53)	2.57 (2.23-2.86)	2.90 (2.50-3.23)	3.37 (2.88-3.75)	3.79 (3.21-4.22)
2-hr	1.10 (0.976-1.24)	1.32 (1.17-1.49)	1.66 (1.47-1.87)	1.97 (1.74-2.20)	2.39 (2.10-2.66)	2.77 (2.41-3.08)	3.17 (2.75-3.52)	3.61 (3.11-4.00)	4.26 (3.63-4.70)	4.84 (4.08-5.34)
3-hr	1.19 (1.05-1.34)	1.42 (1.26-1.60)	1.77 (1.57-2.00)	2.09 (1.85-2.35)	2.54 (2.23-2.85)	2.94 (2.56-3.28)	3.37 (2.92-3.76)	3.85 (3.32-4.2)	4.56 (3.91-5.35)	5.20 (4.57-6.30)
6-hr	1.48 (1.28-1.73)	1.76 (1.53-2.06)	2.17 (1.88-2.53)	2.55 (2.20-2.96)	3.08 (2.64-3.57)	3.55 (3.04-4.10)	4.07 (3.45-4.69)	4.64 (3.91-5.35)	5.48 (4.57-6.30)	6.24 (5.14-7.16)
12-hr	1.83 (1.60-2.15)	2.17 (1.90-2.54)	2.66 (2.33-3.11)	3.12 (2.72-3.64)	3.79 (3.27-4.40)	4.38 (3.76-5.07)	5.03 (4.28-5.87)	5.76 (4.85-6.64)	6.86 (5.69-7.89)	7.86 (6.44-9.02)
24-hr	2.18 (1.96-2.45)	2.61 (2.34-2.94)	3.25 (2.91-3.65)	3.80 (3.39-4.26)	4.63 (4.09-5.18)	5.37 (4.69-6.0)	6.19 (5.33-6.93)	7.11 (6.05-7.97)	8.54 (7.09-9.61)	9.78 (7.98-11.0)
2-day	2.55 (2.32-2.83)	3.05 (2.78-3.38)	3.79 (3.44-4.20)	4.42 (4.00-4.90)	5.39 (4.82-5.97)	6.24 (5.53-6.91)	7.19 (6.30-7.97)	8.26 (7.13-9.18)	9.92 (8.39-11.1)	11.4 (9.45-12.8)
3-day	2.77 (2.56-3.03)	3.31 (3.05-3.61)	4.06 (3.74-4.43)	4.70 (4.31-5.13)	5.64 (5.12-6.16)	6.45 (5.79-7.06)	7.33 (6.51-8.06)	8.30 (7.26-9.23)	9.97 (8.40-11.1)	11.4 (9.49-12.8)
4-day	3.00 (2.80-3.23)	3.57 (3.33-3.85)	4.34 (4.04-4.67)	4.98 (4.62-5.36)	5.89 (5.42-6.36)	6.66 (6.06-7.22)	7.46 (6.72-8.15)	8.33 (7.39-9.27)	10.0 (8.41-11.2)	11.5 (9.54-12.9)
7-day	3.49 (3.27-3.74)	4.14 (3.87-4.44)	4.96 (4.63-5.32)	5.63 (5.24-6.05)	6.57 (6.06-7.07)	7.32 (6.70-7.91)	8.09 (7.34-8.80)	8.89 (7.98-9.75)	10.1 (8.82-11.3)	11.6 (9.63-13.0)
10-day	4.03 (3.80-4.29)	4.75 (4.48-5.06)	5.60 (5.28-5.96)	6.28 (5.90-6.68)	7.19 (6.70-7.67)	7.89 (7.32-8.45)	8.60 (7.91-9.26)	9.32 (8.49-10.1)	10.3 (9.26-11.4)	11.7 (9.91-13.1)
20-day	5.65 (5.37-5.96)	6.61 (6.28-6.98)	7.60 (7.22-8.04)	8.41 (7.96-8.90)	9.47 (8.92-10.0)	10.3 (9.63-11.0)	11.1 (10.3-11.9)	11.9 (11.0-12.8)	12.9 (11.8-14.1)	13.7 (12.3-15.0)
30-day	7.11 (6.78-7.46)	8.28 (7.90-8.71)	9.40 (8.95-9.89)	10.3 (9.78-10.8)	11.4 (10.8-12.0)	12.3 (11.6-13.0)	13.1 (12.3-13.9)	13.9 (13.0-14.8)	14.9 (13.8-16.0)	15.6 (14.3-16.9)
45-day	9.09 (8.70-9.50)	10.5 (10.1-11.0)	11.8 (11.3-12.4)	12.8 (12.3-13.5)	14.1 (13.4-14.8)	15.1 (14.3-15.9)	15.9 (15.1-16.9)	16.8 (15.8-17.8)	17.8 (16.6-19.0)	18.5 (17.1-19.9)
60-day	10.9 (10.5-11.4)	12.7 (12.2-13.3)	14.1 (13.5-14.8)	15.3 (14.6-16.0)	16.7 (15.9-17.5)	17.7 (16.8-18.7)	18.7 (17.7-19.7)	19.6 (18.4-20.8)	20.6 (19.3-22.0)	21.4 (19.9-22.9)

Calculation Step 2

¹ Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS). Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values. Please refer to NOAA Atlas 14 document for more information.



PROJECT / PROPOSAL NAME / LOCATION: Mount Storm - Settling Capacity Analysis	PROJECT / PROPOSAL NO. 230765.0000 Phase 4	FINAL
PREPARED BY: D. Engstrom	DATE: 9/21/2015	REVISION
CHECKED BY: J. Hotstream	DATE: 9/23/2015	10/28/2015

SUMMARY OF FLOW DATA AND CALCULATIONS

Method:

Flow data into the primary settling ponds (Ponds A and B) were not available to estimate treatability of influent. Flow ranges are estimated based on monthly monitoring of the permitted outfall to Mt. Storm Lake since 2001 and calculated flows from the weir in the Pond A/B distribution box.

Data from Monitoring Point 401 represents the outfall after Ponds C and D. It is assumed that this flow is equal to the inflow to the ponds. Calculated influent flow values are based on water heights over the weir in the Pond A/B distribution box obtained on 8/24, 8/25, and 8/27/15. Several calculated flows are plotted on Figure 1

Figure 1:





Table 1. Statistical summary of the Outfall 401 flow data.

STATISTICAL PARAMETER	FLOW (MGD)
Average	10.6
Maximum	28.3
Minimum	2.8
Median	10.3
Standard Deviation	3.7
Lower Quartile	8.04
Upper Quartile	13.5
Average Plus Two Standard Deviations	18.0
Adjusted Maximum	28.3

Calculation Step 3.

Discussion:

Fifteen years of data from Outfall 401 provides maximum flow of 28.3 MGD, a minimum flow of 2.8 MGD, and an average flow of 10.6 MGD. These data from Outfall 401 are normally distributed. Therefore considering a value of the mean and 2 standard deviations, 18 MGD, captures 95%+ of the population. Recent data, from 2010 to present, suggest maximum flows of 15 MGD. Comparing this analysis to field measurements at the weir support a maximum flow value of 18 MGD (27.85 cfs).



- NOTES**
- REFER TO PLAN SHEET 66703-2 AND C1 OF THIS PLAN SET FOR GENERAL NOTES AND CIVIL STANDARD LEGEND.
 - REFER TO PLAN SHEET 66703-C21 FOR NEW PIPING LAYOUTS.


STAGE VS STORAGE MATRIX

ELEVATION	POND A CAPACITY (GAL)	POND A CAPACITY (AC FT)
3,247	40,400	0.1
3,248	198,500	0.6
3,249	502,500	1.5
3,250	844,000	2.6
3,251	1,211,100	3.7
3,252	1,604,100	4.9
3,253	2,023,700	6.2
3,254	2,470,200	7.6
3,255	2,944,000	9.0
3,256	3,445,600	10.6
3,257	3,975,300	12.2

STAGE VS STORAGE MATRIX

ELEVATION	POND B CAPACITY (GAL)	POND B CAPACITY (AC FT)
3,247	43,100	0.1
3,248	207,300	0.6
3,249	507,800	1.6
3,250	846,400	2.6
3,251	1,210,400	3.7
3,252	1,600,400	4.9
3,253	2,016,700	6.2
3,254	2,460,000	7.5
3,255	2,930,600	9.0
3,256	3,429,200	10.5
3,257	3,956,100	12.1

Calculation Step 4



POWER GENERATION ENGINEERING RICHMOND, VIRGINIA			
OVERVIEW – PYRITE POND, PONDS A AND B SUBGRADE PLAN			
LWSP – PHASE 2 – 2017 & 2018 CONSTRUCTION MOUNT STORM POWER STATION, WEST VIRGINIA			
DSGN	D.MARSHALL	DSGN SUPV	_____
DRWN	L.STORMER	ENGR SUPV	_____
CHKD	JNH	PROJ ENGR	_____
DATE: JUNE 2016		DATE DGN SPEC FOR FILE VERIFICATION	
DRAWING NO. 66703-C6		REV. 0	
SCALE: AS NOTED		UNLESS OTHERWISE NOTED	
SH		C6 OF 71	

0 ISSUED FOR BID															06 06 2016	DM	LLS	JNH	NA	X	RKN	CBS	SM	BCA	X	X	E.M.	I&C	ENGR									
REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR	REV	DATE	DSGN	DRWN	CHKD	DSGN SUPV	PROJ ENGR	CIVIL ENGR	ELEC ENGR	MECH ENGR	ARCH	E.M. ENGR	I&C ENGR