

## Groundwater Protection Standard Exceedance Notification

### Possum Point Power Station – Pond D Dumfries, Virginia

Until the last few years, coal had been the primary source of electric generation in Virginia and in the U.S. generally. As we now transition to the cleaner energy sources of the future we will continue to be responsible for managing coal ash to ensure a clean and safe environment for the communities we call home.

**This notification provides groundwater sampling results for Possum Point Power Station. There are no impacts to drinking water or public health. Likewise, historical water sampling in Quantico Creek demonstrates aquatic life as well as recreational activities (swimming, boating, fishing, etc.) continue to be protected.**

Dominion Energy takes these results very seriously. Any impact or potential impact to our environment has our full attention. We are committed to doing any clean-up necessary in accordance with all federal and state regulations, but more importantly we are committed to doing what is right.

Groundwater protection standards (GWPS) for the Possum Point Power Station Pond D (Pond D) were established in accordance with the federal Coal Combustion Residual (CCR) Rule on October 31, 2018. The CCR rule establishes the requirements for GWPS and measures to be taken to address groundwater conditions at ash impoundments and landfills. Groundwater samples were collected from the impoundment’s groundwater monitoring network, which consists of eight (8) monitoring wells and analyzed for the twenty-one (21) required CCR constituents. The analytical results were then compared to GWPS. All results were below the GWPS.

**CCR Rule Groundwater Protection Standard Exceedances**

Constituent	GWPS (parts per billion)	Downgradient Monitoring Well(s)	Concentration (parts per billion)
None	--	--	--

The Commonwealth of Virginia adopted by reference the October 4, 2016 version of the federal CCR rule 40 CFR §257 into 9VAC20-81-800 of the Virginia Solid Waste Management Regulations. Amendments to 40 CFR §257 after October 4, 2016 were not incorporated into Virginia CCR impoundment rules (9VAC20-81-800). As a result, health-based GWPSs adopted under the August 29, 2018 amendment to the Federal CCR Rule are not applicable to 9VAC20-81-800. Even with the application of the more stringent background based Virginia CCR program, only two constituents in three wells were detected at a concentration above its Virginia CCR GWPS. Groundwater within the property and downgradient of the property is not used as drinking water and these concentrations do not represent a risk to human health or the environment.

**Virginia CCR Rule Groundwater Protection Standard Exceedances**

<b>Constituent</b>	<b>GWPS (parts per billion)</b>	<b>Downgradient Monitoring Well(s)</b>	<b>Concentration (parts per billion)</b>
Cobalt	1 <sup>(1)</sup>	ED-1605	5.8
Lithium	25 <sup>(1)</sup>	ED-9R2	33.3
		SD-1603	29.0

<sup>(1)</sup> = Values represent highest laboratory Quantitation Limit (QL) for the constituent based on background data.  
 Future QL values are subject to change; however, GWPS cannot be less than the value listed.