



Date of Inspection: 6/16/2017
 Facility: Possum Point Pond E

Annual Inspection Report for Existing CCR Surface Impoundment

Reference: 40 CFR Section 257.83, *Inspection Requirements for CCR Surface Impoundments*

Owner Information

Name of Dam: Possum Point Ash Pond E Dam
 Owner's Name: Virginia Electric and Power Company
 State ID #: DCR Inventory #15321
 Owner Contact: Jeff Marcell 703-441-3813
 Dam Location: Dumfries, Virginia

Engineer Information

Name and Virginia License Number: Daniel McGrath 040703
 Firm Name: Golder Associates Inc.
 Firm Address: 2108 W. Laburnum Ave, Suite 200, Richmond, VA 23227
 Telephone No.: 804-358-7900

Certification Statement

I certify that the inspection of the above listed CCR surface impoundment was conducted in conformance with the requirements listed in 40 CFR 257.83, and with generally accepted good engineering practices.



Engineer seal, signature and date

As used herein, the word certify shall mean an expression of the Engineer's professional opinion to the best of his or her information, knowledge and belief, and does not constitute a warranty or guarantee by the Engineer



Date of Inspection:
 Facility:

	Yes	No
Was a review performed of available information regarding the status of the CCR unit, including files in the operating record?	X	

Was a visual inspection performed (i) to identify signs of stress or malfunction of the CCR unit and appurtenant structures, and (ii) of all hydraulic structures underlying the base or passing through the dike of the CCR unit for structural integrity and safe and reliable operation?	X	
---	---	--

Identify any changes in the geometry of the impounding structure since the previous annual inspection.

Verify the type, location, and condition of existing instrumentation (e.g. flow meter or staff gauge). Document the maximum recorded readings of each instrument since the previous annual inspection.

List the minimum, maximum, and present depth and elevation of impounded water and CCR since the previous annual inspection.

Minimum Depth (ft)	<input type="text" value="3.0"/>	Maximum Depth (ft)	<input type="text" value="6.0"/>	Present Depth (ft)	<input type="text" value="3.0"/>
Minimum Elev. (Ft)	<input type="text" value="-3.0"/>	Maximum Elev. (ft)	<input type="text" value="0.0"/>	Present Elev. (ft)	<input type="text" value="-3.0"/>

(WATER ONLY, NO CCR OBSERVED)

Present Storage Capacity: Ac - Ft.

Present volume of the impounded water and CCR: Ac - Ft.

Identify any appearances of an actual or potential structural weakness of the CCR unit or existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit and appurtenant structures.

Identify any changes that may have affected the stability or operation of the impounding structure since the previous annual inspection.



Date of Inspection: 6/16/2017
Facility: Possum Point Pond E

Additional comments

Ash Pond E meets the definition of an inactive surface impoundment under 40CFR 257.53 of the "Standards for the Disposal of Coal Combustion Residuals (CCR) in Landfills and Surface Impoundments". Pond E no longer receives CCRs and at the time of my visit had a small volume of standing stormwater.