




ANNUAL CCR FUGITIVE DUST CONTROL REPORT

Virginia Electric and Power Company
Possum Point Power Station
19000 Possum Point Road
Dumfries, Virginia 22026

December 15, 2017



Purpose

The Annual Coal Combustion Residuals (CCR) Fugitive Dust Control Report is produced by Virginia Electric and Power Company d/b/a Dominion Energy Virginia to comply with 40 CFR 257.80(c). This report documents actions to control fugitive dust during the annual period from October 15, 2016 to October 14, 2017.

Description of Fugitive Dust Controls

The Possum Point Power Station employs industry accepted practices for controlling CCR fugitive dust from its operations at Ponds A, B, C, D, and E including the following:

Fugitive Dust Control Practice	Description
Conditioning of CCR	CCR materials are conditioned with water prior to loading into trucks for transport.
Covered containers	Transport containers are maintained covered whether staged or in transport.
Speed limits/Access control	Speed limits are strictly enforced and access is controlled to minimize dust generation from vehicle travel.
Water spray of roads	Roads are sprayed routinely to minimize dust from operations and weather.
Road sweeping/scraping	Spilled or tracked CCR is promptly swept or scraped to remove from road or operating area.
Compaction	CCRs are compacted throughout the daily operations to limit loose materials.

Citizen Complaints

No citizen complaints were received during the annual period covered by this report.

Corrective Actions

The CCR fugitive dust controls are sufficient and no corrective actions were necessary.