


**CCR SURFACE IMPOUNDMENT LOCATION RESTRICTIONS DEMONSTRATION
POSSUM POINT POWER STATION PONDS ABC and E**

The Possum Point Power Station (“Station”) is located in Prince William County, Virginia at 19000 Possum Point Road, Dumfries, Virginia. The Station includes four inactive Coal Combustion Residuals (“CCR”) surface impoundments, Ponds ABC and E, as defined by the Federal Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule and as amended on August 5, 2016 (40 C.F.R. Part 257, Subpart D; “CCR rule”). Under the CCR rule, owner/operators of inactive surface impoundments are required to develop a location restriction demonstration no later than April 16, 2020. The location restriction demonstration is required to ensure that the surface impoundments are appropriately sited. Under Section 257.60(c)(4), surface impoundments without successful demonstrations by this date are required to cease placement of CCR material and commence closure. Pursuant to the Station's Solid Waste Permit (SWP #617), Ponds ABC and E have commenced closure and have been fully excavated of CCR material and completed a minimum 6 inch over excavation of subsurface material. As the subject ponds have commenced closure and all CCR material has been removed, there is no longer a need to perform a Location Restrictions Demonstration for these units under the CCR rule.

Daniel McGrath, P.E.
Printed Name of Professional Engineer

040703
Commonwealth of Virginia License No.



Signature and Date of Professional Engineer