



Facility Inspected	<input type="checkbox"/> Chesterfield Landfill	<input type="checkbox"/> Clover Landfill	<input type="checkbox"/> Mt. Storm Phase A Landfill
	<input checked="" type="checkbox"/> VCHEC Landfill	<input type="checkbox"/> Yorktown Landfill	<input type="checkbox"/> Mt. Storm Phase B Landfill


Date of Inspection	October 19, 2016	Inspected By:	James F. Shields
Professional Engineer	James F. Shields	Virginia PE Registration Number	0402055777

Professional Engineer Certification Statement

I certify that the inspection of the above listed CCR Landfill was conducted in conformance with the requirements listed in 40 CFR Section 257.84, *Inspection Requirements for CCR Landfills*, and with generally accepted good engineering practices. This Certification/Statement of Professional Opinion is limited to the information available to GAI Consultants at the time the site visit was performed. The use of the words "certification" and/or "certify" in this document shall be interpreted and construed as a Statement of Professional Opinion and is not and shall not be interpreted or construed as a guarantee, warranty, or legal opinion.

Print Name:	James F. Shields	Title:	Assistant Engineering Manager
Signature:	<i>James Shields</i>	Date:	10/26/16

Place Stamp Here



Inspection Results – VCHEC Landfill

Was a review performed of available information regarding the status and condition of the CCR unit, including files in the operating record?

Yes No

Was a visual inspection performed to identify signs of stress or malfunction of the CCR unit?

Yes No

Identify any changes in the geometry of the unit since the previous annual inspection.

The remaining portion of Stage 1B was issued a certificate to operate on August 10, 2016. CCR placement continues in accordance with the Station's approved plans and specifications.

Present volume of the CCR contained in the unit at the time of the inspection (cubic yards)

5,100,900

Identify any appearances of an actual or potential structural weakness of the CCR unit or existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit.

None observed.

Identify any changes that may have affected the stability or operation of the unit since the previous annual inspection.

None observed.

Additional comments

No additional comments.