

SOUTH CAROLINA ELECTRIC & GAS



UNSTABLE AREAS CERTIFICATION

FOR THE
**WATEREE STATION
LANDFILL**
RICHLAND COUNTY, SOUTH CAROLINA

OCTOBER 2018



1 OVERVIEW

The EPA Administrator, Gina McCarthy, signed the Disposal of Coal Combustion Residuals from Electric Utilities final rule on December 19, 2014, and it was published in the Federal Register (FR) on April 17, 2015. The regulations provide a comprehensive set of requirements for the safe disposal of coal combustion residuals (CCRs), commonly known as coal ash, from coal-fired power plants. The rule will be administered as part of the Resource Conservation and Recovery Act [RCRA, 42 United States Code (U.S.C.) §6901 et seq.], using the Subtitle D approach.

South Carolina Electric & Gas (SCE&G) is subject to the CCR Rule. Based on SCE&G's review of the rule, the **Class Three Landfill** at **SCE&G Wateree Station** has been determined to be an existing CCR landfill subject to the CCR rule requirements.

2 PURPOSE

The purpose of this report is to document that the Wateree Station Class Three Landfill meets the requirements of CCR rule §257.64 – *Unstable Areas*.

3 APPLICABLE REGULATIONS

CCR rule §257.64 – *Unstable Areas* states the following:

(a) An existing or new CCR landfill, existing or new CCR surface impoundment, or any lateral expansion of a CCR unit must not be located in an unstable area unless the owner or operator demonstrates by the dates specified in paragraph (d) of this section that recognized and generally accepted good engineering practices have been incorporated into the design of the CCR unit to ensure that the integrity of the structural components of the CCR unit will not be disrupted.

(b) The owner or operator must consider all of the following factors, at a minimum, when determining whether an area is unstable:

(1) On-site or local soil conditions that may result in significant differential settling;

(2) On-site or local geologic or geomorphologic features; and

(3) On-site or local human-made features or events (both surface and subsurface).

4 CLASS THREE LANDFILL DESCRIPTION

Wateree Station is coal-fired electric generation plant located along the Wateree River near Eastover, Richland County, South Carolina. The Class Three landfill associated with the plant is entirely located within the property boundaries of Wateree Station. The landfill facility is comprised of 18 landfill cells, planned for development in multiple phases and encompassing a total of approximately 141 lined acres.

The active disposal unit was constructed in accordance with the construction permit (permit # LF3-00026) issued from the South Carolina Department of Health and Environmental Control (DHEC) on September 30, 2008, modified on June 28, 2013. Cells 1 through 5, encompassing approximately 34-acres, were placed into operation in accordance with an operation approval issued by DHEC on April 21, 2010. Cells 6 through 9, encompassing an additional approximate 37-acres, were placed into operation in accordance with an operation approval issued by DHEC on February 2, 2015.

5 UNSTABLE AREAS DISCUSSION

For purposes of this review, EPA's CCR rules (to include reference to *EPA Solid Waste Disposal Facility Criteria, Technical Manual – EPA530-R-93-017*) has defined the following:

(1) Unstable area means a location that is susceptible to natural or human-induced events or forces capable of impairing the integrity of some or all of the landfill structural components responsible for preventing releases from a landfill. Unstable areas can include poor foundation conditions, areas susceptible to mass movements, and Karst terrains.

(2) Structural components means liners, leachate collection systems, final covers, run-on/run-off systems, and any other component used in the construction and operation of the MSWLF that is necessary for protection of human health and the environment.

(3) Poor foundation conditions means those areas where features exist which event may result in inadequate foundation support for the structural components of a MSWLF unit.

(4) Areas susceptible to mass movement means those areas of influence (i.e., areas characterized as having an active or substantial possibility of mass movement) where the movement of earth material at, beneath, or adjacent to the MSWLF unit, because of natural or man induced events, results in the downslope transport of soil and rock material by means of gravitational influence. Areas of mass movement include, but are not limited to, landslides, avalanches, debris slides and flows, solifluction, block sliding, and rock fall.

(5) Karst terrains means areas where karst topography, with its characteristic surface and subterranean features, is developed as the result of dissolution of limestone, dolomite, or other soluble rock. Characteristic physiographic features present in karst terrains include, but are not limited to, sinkholes, sinking streams, caves, large springs, and blind valleys.

Natural Unstable Areas

EPA states that natural unstable areas include those areas that:

- *Have poor soils for foundations;*
- *Are susceptible to mass movement;*
- *Have karst features.*

As part of the investigation and design for the landfill, a hydrogeological site characterization and stability assessment were conducted to evaluate subsurface conditions, to analyze slope stability, to identify any potentially hazardous site conditions, and to provide an examination of any related design needs (reports: *SCE&G Wateree Station Landfill, Permit Modification Cells 6-18*, November 2012; *SCE&G Wateree Station Industrial Solid Waste Landfill, Hydrogeological Characterization Report*, December 2006; *SCE&G Wateree Station Industrial Solid Waste Landfill Permit Application – Landfill Location Restriction Study*, December 2006; *Wateree Station Industrial Solid Waste Landfill Permit Application*, December 2006). The assessments included investigating the geotechnical and geological characteristics of the site to establish soil strengths and other engineering properties using field and laboratory tests. The assessments also included a seismic hazard analysis, static and seismic slope stability and foundation settlement to identify any poor foundation conditions or areas susceptible to mass movement. Published USGS and other local pertinent geologic literature identify no known Karst terrain in the area of the site, which was confirmed through the hydrogeologic site investigation. Based on my review of the facility's hydrogeological site characterization and stability assessment reports, the landfill site is not located in an unstable area.

Moreover, as part of the construction for the landfill, a construction quality assurance and geotechnical program was utilized to provide construction observation and monitoring of the natural foundation conditions for the landfill. Based on my review of the construction quality assurance and geotechnical program reports (report *SCE&G Wateree Station Landfill, Construction Certification Report Cells 1-5*, March 2010; *SCE&G Wateree Station Landfill, Phase 2 (Cells 6-9) Construction Certification Report*, January 2015) and my observations during landfill construction, the landfill's natural foundation conditions were firm and unyielded with no evidence of the landfill site being located in an unstable area observed.

Human-Induced Unstable Areas

EPA states that examples of human-induced unstable areas conditions include:

- *The presence of cut and/or fill slopes during construction of the waste unit may cause slippage of existing soil or soils, adjacent embankments, and slopes; rock;*
- *Excessive drawdown of ground water increases the effective overburden on the foundation soils underneath the waste unit, which may cause excessive settlement or bearing capacity failure on the foundation soils;*
- *Closed landfill as the foundation for a new landfill (“piggy-backing”) may be unstable unless the closed landfill has undergone complete settlement of the underling wastes.*

As part of the construction for the landfill, a construction quality assurance program was utilized to provide observation and monitoring of the natural foundation conditions, foundation excavations and structural fill placement for the landfill. Based on my review of the construction quality assurance reports (report *SCE&G Wateree Station Landfill, Construction Certification Report Cells 1-5*, March 2010; *SCE&G Wateree Station Landfill, Phase 2 (Cells 6-9) Construction Certification Report*, January 2015) and my

observations during landfill construction, all cut and fill slopes during construction were stable and did not cause slippage of existing soils or soils, adjacent embankments and slopes.

With regards to groundwater drawdown, the landfill is developed to maintain sufficient separation from groundwater with no drawdown of groundwater at or in the vicinity of the landfill necessary or occurred/planned for landfill related or other site purposes. Additionally, the Wateree landfill is founded on native undisturbed soils and is not founded over any landfilled waste (“piggy-backing”).

Based on the above discussions, the landfill is not located in a human-induced unstable area.

6 CONCLUSION

Based on my review of the facility records and my observations during the development of the landfill as discussed above, the Wateree Station Class Three Landfill is not located in an Unstable Area and meets the requirements of CCR rule §257.64 – *Unstable Areas*.