

Date of Inspection: 11/18/2020

Facility: YT Ash Landfill

Annual Inspection Report for CCR Landfills

Reference: 40 CFR Section 257.84, Inspection Requirements for CCR Landfills

Owner Information

Name of Landfill: Yorktown Power Station Ash Landfill

Owner's Name: Virginia Electric and Power Company, d.b.a. Dominion Energy

State ID #: Solid Waste Permit #457

Owner Contact: Krystal Gill, Senior Environmental Compliance Coordinator

Landfill Location: Yorktown, VA

Engineer Information

Name and Virginia License Number: Andrew T. North 053724


Firm Name: Golder Associates Inc.

Firm Address: 2108 W. Laburnum Ave, Suite 200, Richmond, VA 23227

Telephone No.: 804-358-7900

Certification Statement

I certify that the inspection of the above listed CCR landfill was conducted in conformance with the requirements listed in 40 CFR 257.84, and with generally accepted good engineering practices.



Engineer seal, signature and date

As used herein, the word certify shall mean an expression of the Engineer's professional opinion to the best of his or her information, knowledge and belief, and does not constitute a warranty or guarantee by the Engineer



Date of Inspection: 11/18/2020
Facility: YT Ash Landfill

	res	NO
Was a review performed of available information regarding the status	Х	
of the CCR unit, including files in the operating record?		
Was a visual inspection performed to identify signs of stress or	Х	
Was a visual inspection performed to identify signs of stress or malfunction of the CCR unit?	_ ^	
manancion of the certaint.		
lem:lem:lem:lem:lem:lem:lem:lem:lem:lem:	inspection	
Phase B closure work has been completed.		
Approximate volume of the CCR contained in the unit at the time of inspection		
1,760,000 cubic yards.		
Identify any appearances of an actual or potential structural weakness of the CC in addition to any existing conditions that are disrupting or have the potential to the operation and safety of the CCR unit		
None observed.		
Identify any other change(s) which may have affected the stability or operation since the previous annual inspection.	of the CCR u	nit
None observed.		
Additional comments		
Piezometers installed in October 2017 to evaluate perched water in the closed F	hase A were	9
decomissioned in April 2020 by Dominion Energy.		
The Yorktown Power Station Ash Landfill (VDEQ Permit No. 457) began its post- August 26, 2020 as stated in a letter by the VDEQ dated September 23, 2020.	closure care	period on