



Automatic Rejection Criteria for Banner and Flag Attachments **Dominion Owned Poles**

The following types of installations **will not be allowed**:

1. Bands or wire wrapping around risers or control cables.
2. Attachments not for public welfare. These include product advertisement.
3. Attachments requested by counties, states, and private entities not providing adequate insurance coverage.
4. Pole to Pole attachments.
5. Attachments exceeding 12 square feet of effective projected area (EPA). The installation may not result in loading that exceeds the allowable strength of the structure.
6. Attachments that violate applicable codes such as; NEC, NESC, or jurisdictional codes including:
 - a. Attachments closer than 9 feet above sidewalks and/or pedestrian passageways. (2017 NESC Table 232-2)
 - b. Attachments closer than 15.0 feet above areas where vehicles are expected to travel or park. This requirement includes areas where riders on horseback may be present. (2017 NESC Table 232-2)
 - c. Attachments closer than 18 feet above VDOT & NCDOT roads.
 - d. Un-energized attachments closer than 12" to telecommunication cables (TELCO & CATV).
 - e. Energized attachments closer than 40" below telecommunications cables (TELCO & CATV).
7. Attachments obstructing the line-of-site of a vehicle driver.
8. Attachments on poles with operating devices such as reclosers, UG terminals, Gang operated switches.
9. Attachments interfering with area lighting.
10. Photocell taps for pole mounted equipment.
11. Rigid support arms for Attachment.
12. Installation on bridges.

*The installer will not be allowed to drill holes or deface Dominion poles. Stainless Steel Bands are the preferred method of attachment.

**This list is not all-inclusive. Design Engineering will approve other types of attachments on a case-by-case basis. Dominion reserves the right to reject any applications for use of its power poles or to change or withdraw or remove the approved attachments at any time after the installation. Should Dominion have to work on or remove a pole with attachments, Dominion is not liable for damaged or lost attachments.